GRSS Conduit Outlet Boxes with Multiple Hubs

Explosionproof, Dust-Ignitionproof, Raintight

UNILETS™ for use with Threaded Metal Conduit. Furnished with Internal Ground Screw and O-ring gasket.

NEC/CEC: Class I, Division 1 and 2, Groups B♦, C, D Class II, Division 1 and 2, Groups E, F, G

Applications

- Complies with a wide range of classified area requirements.
- Corrosion-resistant: ideal indoors or out.
- For pulling of wires.
- Connect conduit lengths and change direction of conduit runs.
- Provide access for maintenance.

Features

- Accurately tapped, tapered hub threads for tight, rigid joints and ground continuity.
- Furnished with covers.
- General purpose wiring.
- Multiple hubs permit flexibility.
- Copperfree aluminum body and cover provide superior corrosion resistance.
- Internal ground screw standard.
- Cover o-ring included.

Standard Materials

• Bodies and covers: copperfree (4/10 of 1% max.) aluminum

Standard Finishes

· Epoxy powder coat

NEC/CEC Certifications and Compliances

- UL Standard: UL 886 (UL 1203)
- UL Listed: E85310
- CSA Standard: C22.2 No. 25, C22.2 No. 30
- CSA Certified: 025875

Box Type	Conduit Size (Inches)	Cover Opening mm (in)	Hubs	Plugs	Capacity dm³ (in³)	Catalog Number *	
GRSS Outlet Bo	x with Cover						
Internally threaded aluminum bodies with externally threaded aluminum form 1 covers. Has 7 hubs; 2 on each of the sides, 1 on the top, 1 on the bottom and 1 on the center in the back. Furnished with 4 close-up plugs and o-ring.							
	1/2	85.9 (3.38)	7	4	0.48 (29.0)	GRSS50	
GRSS	3/4	85.9 (3.38)	7	4	0.48 (29.0)	GRSS75	
	1	85.9 (3.38)	7	4	0.48 (29.0)	GRSS100	

GRSSA Outlet Box with Cover

Internally threaded aluminum bodies with externally threaded aluminum form 1 covers. Has 13 hubs; 2 on each side, 2 each on top and bottom and 5 in the back.


Furnished with 5 close-up plugs and o-ring.

GRSSA	3/4	85.9 (3.38)	13	5	0.48 (29.0)	GRSSA75
	1/2	85.9 (3.38)	13	5	0.48 (29.0)	GRSSA50

Replacement Parts

Replacement Cover	GRK1
Replacement O-Ring	GRG1

Dimensions in Millimeters (Inches)



♦ In Class I, Division 1, Group B atmospheres, all conduit runs must have a sealing fitting (not supplied) field-installed within 2" to the enclosure.

