

# EDS Mounting Bodies for Contender® Series Tumbler Switches

Furnished with Internal Ground Screw.

Class I, Division 1, Groups C, D  
 Class I, Division 2, Group B, C, D  
 Class II, Division 1 and 2, Groups E, F, G  
 Class III

Controls

CONTROLS: HAZARDOUS LOCATION CONTROL STATIONS AND SWITCHES

|                                                                                     |           | Catalog Number    |                |            |
|-------------------------------------------------------------------------------------|-----------|-------------------|----------------|------------|
| Type                                                                                |           | Hub Size (Inches) | Malleable Iron | Aluminum   |
| 1-Gang                                                                              |           |                   |                |            |
|    | Dead-End  | 1/2               | EDS171         | EDS171-SA  |
|                                                                                     |           | 3/4               | EDS271         | EDS271-SA  |
|                                                                                     |           | 1                 | EDS371         | EDS371-SA  |
|                                                                                     | Feed-Thru | 1/2               | EDSC171        | EDSC171-SA |
|                                                                                     |           | 3/4               | EDSC271        | EDSC271-SA |
|                                                                                     |           | 1                 | EDSC371        | EDSC371-SA |
| 2-Gang                                                                              |           |                   |                |            |
|   | Dead-End  | 1/2               | EDS172         | EDS172-SA  |
|                                                                                     |           | 3/4               | EDS272         | EDS272-SA  |
|                                                                                     |           | 1                 | EDS372         | EDS372-SA  |
|                                                                                     | Feed-Thru | 1/2               | EDSC172        | EDSC172-SA |
|                                                                                     |           | 3/4               | EDSC272        | EDSC272-SA |
|                                                                                     |           | 1                 | EDSC372        | EDSC372-SA |
| Tandem †                                                                            |           |                   |                |            |
|  | Dead-End  | 1/2               | EDS177         | EDS177-SA  |
|                                                                                     |           | 3/4               | EDS277         | EDS277-SA  |
|                                                                                     |           | 1                 | EDS377         | EDS377-SA  |
|                                                                                     | Feed-Thru | 1/2               | EDSC177        | EDSC177-SA |
|                                                                                     |           | 3/4               | EDSC277        | EDSC277-SA |
|                                                                                     |           | 1                 | EDSC377        | EDSC377-SA |

† For tandem bodies, external seals must be installed within 5 feet/1.5 meters of each conduit entrance for Class I, Groups C and D.