



Underwriters Laboratories Inc.®

Northbrook, Illinois • (847) 272-8800
Melville, New York • (516) 271-6200
Santa Clara, California • (408) 985-2400
Research Triangle Park,
North Carolina • (919) 549-1400
Camas, Washington • (360) 817-5500

CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 180998-E84967B
ISSUE DATE: September 18, 1998

Issued to: Square D Company
3700 6th Street S. W.
Cedar Rapids, IA 52404-3069, USA

Report Reference: E84967, May 3, 1996

This is to Certify that representative samples of: Molded Case Circuit Breakers, Catalog Number prefix EJ Series 1

Have been investigated by Underwriters Laboratories Inc. in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL-489, Molded Case Circuit Breakers and Circuit Breaker Enclosures

Additional Information:

These are one, two and three pole circuit breakers rated from 15 A Through 125 A.

Two pole breakers maybe marked 1Ø - 3Ø and carry the 480Y/277V interrupting ratings.

15 A & 20 A maybe marked 'SWD'

15 A through 30 A maybe marked 'HID'

All breakers maybe marked 'HACR'

Cat. Prefix	Poles	Ampere	Current Interrupting Rating
EJ	1	15 - 70	120V, 100kA AIC
EJ	2, 3	15 - 70	240V & 277V, 65kA AIC 240 V, 100kA AIC 480Y/277V, 65kA AIC
		80 - 125	240V, 100kA AIC

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes four elements as follows: the name "Underwriters Laboratories Inc." in various forms and type styles, or abbreviations such as "Und. Lab. Inc.", or the symbol "UL in a circle" (UL); the word "Listed"; a control number (may be alphanumeric) assigned by UL; and the product or category name (product identifier), as indicated in the appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer: *Lawrence Smith*
Underwriters Laboratories Inc.
Lawrence Smith

Review Engineer: *Jeffrey Hidaka*
Underwriters Laboratories Inc.
Jeffrey Hidaka