

CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 120303-E84967

ISSUE DATE: March 12, 2003

Page 1 of 1

Issued to: Square D Company
3700 6th Street S.W.
Cedar Rapids, IA. 52404-3069 USA

Report Reference: E84967, May 3, 1996

**This is to Certify that
representative samples of:** Molded Case Circuit Breakers, Catalog Number prefix ED, EG, EJ and EK
series 1


**Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s)
indicated on this Certificate.**

Standard(s) for Safety: UL 489, the Standard for Molded-Case Circuit Breakers, Molded-Case Switches
and Circuit-Breaker Enclosures

CSA C22.2 No. 5-02, the Standard for Molded-Case Circuit Breakers, Molded-
Case Switches and Circuit-Breaker Enclosures

Additional Information: Circuit Breakers, 1 pole, 70A max, 347Vac max; 2- and 3- pole, 125A max; 480Y/277 Vac max; 2-
and 3- pole 110A max 600Y/347Vac max, Catalog No. Prefix ED, EG and EJ series 1.
Circuit Breakers, 1 pole, 30A max, 347/Vac max, Catalog No. Prefix EK, series 1.
Two pole breakers may be marked 1ph -3ph.
15A and 20A maybe marked "SWD"
15A through 30A may be marked "HID"
All breakers may be marked "HACR"

**Only those products bearing the UL Listing Mark for the US and Canada should be considered
as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements
for US and Canada.**

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers;  the word
"LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the
appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer: *Lawrence R. Smith*
Lawrence R. Smith, Lead Engineering Assoc.
Underwriters Laboratories Inc.

Review Engineer: *Antonio J. Romanacce*
Antonio Romanacce, Engineering Team Leader
Underwriters Laboratories Inc.

