

Northbrook, Illinois • (847) 272 9800 Melville, New York • (516) 271–6200 Santa Clara, California • (408) 985–2400 Research Triangle Park, North Carolina • (919) 549–1400 Camas, Washington • (360) 817–5500

## **CERTIFICATE OF COMPLIANCE**

	CERTIFICATE NUMBER: 121196 - E48340A
	ISSUE DATE: November 12, 1996
Issued to:	Square D Company 3700 6th Street SW Cedar Rapids, IA 52404 USA
Report Reference:	E48340, December 23, 1983
This is to Certify that representative sample	s of: Molded Case Circuit Breakers and Ground Fault Circuit Interrupters, Type QO and QOB, Series
Have been investigate indicated on this Cert	d by Underwriters Laboratories Inc. in accordance with the Standard(s) ificate.
Standard(s) for Safety	UL 489, Molded Case Circuit Breakers and Circuit Breaker Enclosures. UL 943 Ground-Fault Circuit Interrupters.
Additional Information	1: The product includes a switched pole and an unswitched pole and is rated 120 V ac, 15, 20, 25 and 30 A, Class A. Interrupting Ratings: 22kA max, 120 V, 60 Hz. Ampere Rating: 15-30. This product is intended to be installed in a Listed panel board or other suitable enclosure, to provide overcurrent protection of conductors and ground fault protection of personnel.
Only those products UL's Listing and Foll	bearing the UL Listing Mark should be considered as being covered b
	lly includes four elements as follows: the name "Underwriters Laboratories Inc." in various
forms and type styles, or al	breviations such as "Und. Lab. Inc.", or the symbol "UL in a circle" - (); the word " Listed" hanumeric) assigned by UL; and the product or category name (product identifier), as indica
	OOK FOR THE UL LISTING MARK ON THE PRODUCT
	learsha Review Engineer: Charg Gato