

Certificate of Compliance

Certificate: 2280972

Master Contract: 214768

Project: 2280972

Date Issued: 2010-03-02

Issued to: Schneider Electric USA, Inc.
Square D
Raleigh (Knightdale) Plant 8001
Knightdale Blvd.
Knightdale, NC 27545
USA

Attention: Mrs. Nancy Gunderson

The products listed below are eligible to bear the CSA Mark shown



Issued by: Daphane Flemings

PRODUCTS

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

- Time delay relays, Models 9050JCK1 through 9050JCK5, followed by letters and/or numbers, open type with dust cover, rated input 12V ac/dc, 24V ac/dc, 48V ac/dc, 120V ac/dc, 240V ac; contacts 10A general purpose at 240V ac, 10A resistive at 28V dc; ½ hp, 240V ac; 1/3 hp, 120V ac; B300; R300.
- Time delay relays, Models 9050JCK6 and 9050JCK7, followed by letters and/or numbers, open type with dust cover, rated input 12V ac/dc, 24V ac/dc, 48V ac/dc, 120V ac/dc, 240V ac; contacts 10A general purpose at 240V ac; 10A resistive at 28V dc; ½ hp, 240V ac; 1/3 hp, 120V ac; B300; R300.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 14 – Industrial Control Equipment
UL Std No. 508 – Industrial Control Equipment

MARKINGS

Listee's name and/or CSA file number 214768, model designation, complete electrical rating in volts, hertz, hp, amps, serial number or date coding, and the CSA Mark appear in a permanent manner on each unit.