



Ref. Certif. No.

FR\_721813

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Switching element  
TesyS Mini-control relay

Name and address of the applicant

SCHNEIDER ELECTRIC INDUSTRIES SAS  
35, rue Joseph Monier 92500 RUEIL-MALMAISON - FRANCE

Name and address of the manufacturer

SCHNEIDER ELECTRIC INDUSTRIES SAS  
35, rue Joseph Monier 92500 RUEIL-MALMAISON - FRANCE

Name and address of the factory

SCHNEIDER ELECTRIC A.S.  
Cizovska 447 39701 PISEK - CZECH REPUBLIC

Note: When more than one factory, please report on page 2

Additional Information on page 2

Ratings and principal characteristics

See Annex

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

/

Model / Type Ref.

CA2SK20..., CA2SK11..., CA3SK20..., CA3SK11..., CA2SKE20...,  
Suppressor modules: LA4SKE1E, LA4SKE1U, LA4SKC1U

Additional information (if necessary may also be reported on page 2)

Supersedes CBTC FR\_709763 dated 25/11/2020.  
Update further to the evolution of the standard(s)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2020  
IEC 60947-5-1:2024

As shown in the Test Report Ref. No. which forms part of this Certificate

25119Y90028

This CB Test Certificate is issued by the National Certification Body



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
33 avenue du Général Leclerc  
92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)

Date: 11/06/2025

Signature

LABORATOIRE CENTRAL DES  
INDUSTRIES ELECTRIQUES  
S.A.S au capital de 15.745.984 €  
RCS Nanterre B 408 363 174  
**Julien GAUTHIER**  
F - 92266 FONTENAY AUX ROSES  
Certification Officer

## ANNEX

### References, ratings and main characteristics:

CA2SK20..., CA2SK11..., CA3SK20..., CA3SK11..., CA2SKE20..  
 .. means Us voltage code, see the following table

code	B7	E7	F7	G7	M7	P7	U7	Q7	V7
Us (V) AC 50/60Hz	24	48	110	120	220	230	240	380	400
	Including suppressor modules LA4SKE1E(24-48VAC/DC), LA4SKE1U(110-250VAC/DC): for use on CA2SK20, CA2SK11, CA2SKE20 relays								
code	JD	BD	CD	ED	SD	-	-	-	-
Us (V) DC	12	24	36	48	72	-	-	-	-
	Including suppressor module LA4SKC1U(24-250VDC) for use on CA3SK20, CA3SK11 relays								

Type of contact elements	X, Y
Number of contacts	1NC+1NO, 2NO
Conventional free air thermal current Ith (A)	10A
Rated insulation voltage Ui (V)	690V
Rated impulse withstand voltage Uimp (kV)	6kV
Utilization category	AC-15, DC-13
Rated operational voltage Ue (V)	120VAC, 440VAC, 125VDC, 600VDC
Rated frequency (Hz)	50/60Hz for AC
Rated operational current Ie (A)	AC-15: Ue/Ie: 120V/6A, 440V/1,64A DC-13: Ue/Ie: 125V/0,55A, 600V/0,1A
Rated conditional short-circuit current (kA)	1kA
kind of protective device	Fuse gG 10A
Suppressor modules:	LA4SKE1E (24-48VAC/DC), LA4SKE1U(110-250VAC/DC), LA4SKC1U(24-250VDC)



LABORATOIRE CENTRAL DES INDUSTRIES ELECTRIQUES - LCIE  
 33 avenue du Général Leclerc  
 92260 Fontenay-aux-Roses, FRANCE  
[www.lcie.fr](http://www.lcie.fr)

Date: 11/06/2025

Signature:   
**Julien GAUTHIER**  
 Certification Officer

