

IEC

IECEE



TM

Ref. Certif. No.

CN71360

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Control Relays

Name and address of the applicant

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the manufacturer

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the factory

*Note: When more than one factory, please report on page 2*Schneider Electric France
2 Rue du Pont Vert, 27100 Le Vaudreuil, France☒ Additional information on page 2

Ratings and principal characteristics

Ui: 690V; Uimp: 6kV; AC-15: Ue/Ie: 120V/6A, 690V/1.04A;
DC-13: Ue/Ie: 125V/1.1A, 600V/0.2A; Ith: 10A; IP20, except
ring lug connection versions IP10

Trademark (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

CAD32, CAD50, CAD32...S207, CAD50...S207,
CAD32...S335, CAD50...S335;Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity with

IEC 60947-1:2020; IEC 60947-5-1:2024

As shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2025CQC-120463

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Mar.20,2025

Signature:

谢肇煦

Xie ZhaoXu



Name of the factory	Address of the factory
PT. Schneider Electric Manufacturing Batam	Jl Beringin Lot 4, Lot 208, Lot 15, Lot 16, DAN Lot 16A BIP Muka Kuning Kel.Muka Kuning Kec. Sungai Beduk – Batam, Indonesia
SCHNEIDER ELECTRIC INDIA PVT LTD	SY NO 99/1, MAMIDIPALLY, Mamidipalle, Balapur, Rangareddy - 500108

Additional information (if necessary)

Date: Mar.20,2025

Signature:


Xie ZhaoXu