



Ref. Certif. No.

CN49837

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product	Time-delay Auxiliary Contact Block
Name and address of the applicant	Schneider Electric Industries SAS 35 Rue Joseph Monier 92500 Rueil-Malmaison, France
Name and address of the manufacturer	Schneider Electric Industries S.A. 20 rue de la Croix blanche - 86361 - Chasseneuil de Poitou - France
Name and address of the factory	Schneider Electric Industries S.A. 20 rue de la Croix blanche - 86361 - Chasseneuil de Poitou - France
<small>Note: When more than one factory, please report on page 2</small>	
Ratings and principal characteristics	Ui:690V;Ith: 10A;AC-15:Ue/Ie:120V/6A, 690V/1.04A;DC-13:Ue/Ie:125V/0.55A, 600V/0.1A;IP20(except for contact block without terminal cover : IP00)
Trademark (if any)	Schneider Electric
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	LADR,LADT,LADS,LAETSD
Additional information (if necessary may also be reported on page 2)	
A sample of the product was tested and found to be in conformity with	IEC 60947-5-1:2016(4th Edition)
As shown in the Test Report Ref. No. which forms part of this Certificate	00901-CB2020CQC-090901

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRESection 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: May.06,2020

Signature: 
Lu Mei

CB 0056077