

IEC**IECEE**

®

TM

Ref. Certif. No.

CN74380

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Auxiliary Contact Block

Name and address of the applicant

Schneider Electric Industries S.A.S
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the manufacturer

Schneider Electric Industries S.A.S
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the factory

*Note: When more than one factory, please report on page 2*PT. Schneider Electric Manufacturing Batam
Jl Beringin Lot 4, Lot 208, Lot 15, Lot 16, DAN Lot 16A,
Batamindo Industrial Park (BIP), Muka Kuning Kel.Muka
Kuning Kec. Sungai Beduk – Batam, Indonesia

Ratings and principal characteristics

Uimp: 6kV; Ui:690V; AC-15:Ue/Ie:120V/6A,690V/1.04A;
DC-13:Ue/Ie:125V/0.55A,600V/0.1A; Ith:10A; IP20 (except
for contact block without terminal cover : IP00)

Trademark (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

LAD8N;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2020;IEC 60947-5-1:2024

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2025CQC-124525

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Dec.03,2025

Signature:

谢肇煦

Xie ZhaoXu