

IEC**IECEE**

®

™

Ref. Certif. No.

CN74208

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Auxiliary Contact Block

Name and address of the applicant

Schneider Electric Industries S.A.S
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the manufacturer

Schneider Electric Industries S.A.S
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the factory

Schneider Electric Industries S.A.
20 rue de la Croix blanche - 86361 - Chasseneuil de Poitou – France*Note: When more than one factory, please report on page 2* Additional information on page 2

Ratings and principal characteristics

Ui: 690V;Uimp: 6kV;Ith: 10A;AC-15: Ue/Ie: 120V/6A,
690V/1.04A;DC-13: Ue/Ie: 125V/0.55A, 600V/0.1A;IP20
(except for contact block without terminal cover: IP00)

Trademark (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

LADN,LADC;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2020;IEC 60947-5-1:2024

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2025CQC-124530

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Dec.03,2025

Signature:

谢肇煦

Xie ZhaoXu





Ref. Certif. No.

CN74208

Name of the factory	Address of the factory
Schneider Electric a. s.	Cizovska 447 - 39701 Pisek - Czech Republic

Additional information (if necessary)

Date: Dec.03,2025

Signature:

Xie ZhaoXu