

IEC

IECEE



TM

Ref. Certif. No.

CN65823

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Motor circuit breaker

Name and address of the applicant

Schneider Shanghai Industrial Control Co., Ltd.
No.629 Suide Road, Putuo District, Shanghai, P.R.China

Name and address of the manufacturer

Schneider Electric Industries SAS
35 Rue Joseph Monier, 92500 Rueil-Malmaison France

Name and address of the factory

*Note: When more than one factory, please report on page 2*Schneider Shanghai Industrial Control Co., Ltd.
No.629 Suide Road, Putuo District, Shanghai, P.R.China

Ratings and principal characteristics

See the Appendix

Trademark (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

GV2ME, GV2LM;

Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity withIEC 60947-2:2016/AMD1:2019; IEC 60947-2:2016(5th
Edition); IEC 60947-1:2007; IEC
60947-1:2007/AMD1:2010; IEC
60947-1:2007/AMD2:2014; IEC 60947-4-1:2018As shown in the Test Report Ref. No. which
forms part of this Certificate00901-CB2024CQC-113177-1,
00901-CB2024CQC-113177-2

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: May.13,2024

Signature:

谢肇煦

Xie ZhaoXu



GV2ME, GV2LM

Uimp: 6kV;

Ui: 690V;

Ue: AC400/415V, AC690V;

In: 0.16A, 0.25A, 0.4A, 0.63A, 1A, 1.6A, 2.5A, 4A, 6.3A, 10A, 14A, 18A, 23A, 25A, 32A;

Over-current release: Thermo-magnetic, Magnetic;

Ics, Icu:

AC400/415V: 32A: Ics: 50%Icu, Icu: 10kA;

23~25A: Ics: 40%Icu, Icu: 15kA;

14~18A: Ics: 50%Icu, Icu: 15kA;

0.16~10A: Ics: 100%Icu, Icu: 100kA;

AC690V:2.5~32A: Ics: 75%Icu, Icu: 3kA;

0.16~1.6A: Ics: 100%Icu, Icu: 100kA;

Selectivity category: A;

Utilization category: AC-3, AC-3e;

Suitable for isolation;

50/60Hz;

Tripping class com.cqc.cms.component.word.CertiAnnexDataModel:10A;

3P

Page 1 of 1

Additional information (if necessary)

Date:

May.13,2024

Signature:

谢肇煦
Xie ZhaoXu