Ref. Certif. No.
CN55413-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Motor Circuit Breaker
Name and address of the applicant	Schneider Electric Industries SAS 35 Rue Joseph Monier 92500 Rueil-Malmaison, France
Name and address of the manufacturer	Schneider Electric Industries SAS 35 Rue Joseph Monier 92500 Rueil-Malmaison, France
Name and address of the factory Note: *When more than one factory, please report on page 2*	Schneider Electric France 6-8, rue du Bailly - BP 97812 -21078- Dijon Cedex France ☑Additional information on page 2
Ratings and principal characteristics	See the Appendix
Trademark / Brand (if any)	Schneider Electric
Customer's Testing Facility (CTF) Stage used	N/A
Model / Type Ref.	GV2ME, GV2RT, GV2P, GV2L, GV2LE;
Additional information (if necessary may also be reported on page 2)	The latest CB certificate No. is CN55413, dated 2022-01-04. The M1 modification is to change parameters.
A sample of the product was tested and found to be in conformity with	IEC 60947-2:2016/AMD1:2019;IEC 60947-2:2016(5th Edition);IEC 60947-4-1:2018
As shown in the Test Report Ref. No. which forms part of this Certificate	00901-CB2021CQC-098612-M1-1, 00901-CB2021CQC-098612-M1-2

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE
Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: http://www.cqc.com.cn

Date: Jun.01,2023

Signature: 谢肇煦
Xie ZhaoXu

CB 0073690

GV2L, GV2LE, GV2ME, GV2P, GV2RT
Uimp: 6kV;
Ui: 690V;
Ue: AC400/415V, AC440V, AC500V, AC690V;
In:
GV2ME, GV2P: 0.16A, 0.25A, 0.4A, 0.63A, 1A, 1.6A, 2.5A, 4A, 6.3A, 10A, 14A, 18A, 23A, 25A, 32A;
GV2RT: 0.4A, 0.63A, 1A, 1.6A, 2.5A, 4A, 6.3A, 10A, 14A, 18A, 23A;
GV2L, GV2LE: 0.4A, 0.63A, 1A, 1.6A, 2.5A, 4A, 6.3A, 10A, 14A, 18A, 25A, 32A;
Over-current release: Thermo-magnetic(GV2ME, GV2RT, GV2P), Magnetic(GV2L, GV2LE);
Ics/Icu:
GV2ME:
Ue: AC400/415V: 100/100kA(GV2ME01~14), 7.5/15kA(GV2ME16~20), 6/15kA(GV2ME21~22), 5/10kA(GV2ME32);
AC690V: 100/100kA(GV2ME01~06), 2.25/3kA(GV2ME07~32);
GV2ME used in association with current limiters:
Ue: AC400/415V(GV1L3): 100/100kA(GV2ME01~14), 50/100kA(GV2ME16~20), 40/100kA(GV2ME21~32);
AC440V(GV1LE): 100/100kA(GV2ME01~14), 37.5/50kA(GV2ME16), 15/20kA(GV2ME20~32);
AC500V: 100/100kA(GV2ME01~10), 50/50kA(GV2ME14), 42/42kA(GV2ME16), 7.5/10kA(GV2ME20~32);
GV2RT:
Ue: AC400/415V: 100/100kA(GV2RT03~14), 7.5/15kA(GV2RT16~20), 6/15kA(GV2RT21);
AC690V: 100/100kA(GV2RT03~06), 2.25/3kA(GV2RT07~21);
GV2P:
Ue: AC400/415V: 100/100kA(GV2P01~16), 25/50kA(GV2P20~32);
AC690V: 100/100kA(GV2P01~06), 8/8kA(GV2P07~08), 6/6kA(GV2P10~16), 4/4kA(GV2P20~32);
GV2P used in association with current limiters:
Ue: AC400/415V(GV1L3): 100/100kA(GV2P01~16), 50/100kA(GV2P20~32);
AC440V(GV1L3): 100/100kA(GV2P01~14), 50/100kA(GV2P16~32);

Additional information (if necessary)

Date: Jun.01,2023

Signature: 谢肇煦
Xie ZhaoXu

CHINA QUALITY CERTIFICATION CENTRE
Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666
Fax: +86-10-83886282
website
http://www.cqc.com.cn

AC500V(GV1L3): 100/100kA(GV2P01~10), 50/100kA(GV2P14~32);
AC690V(LA9LB920): 100/100kA(GV2P01~06), 50/50kA(GV2P07~32);
GV2L:
Ue: AC400/415V: 100/100kA(GV2L03~14), 25/50kA(GV2L16~20, GV2L22~32);
AC690V: 100/100kA(GV2L03~05), 4/4kA(GV2L06~20, GV2L22~32);
GV2LE:
Ue: AC400/415V: 100/100kA(GV2LE03~14), 7.5/15kA(GV2LE16~20), 6/15kA(GV2LE22), 5/10kA(GV2LE32);
AC690V: 100/100kA(GV2LE03~06), 2.25/3kA(GV2LE07~20, GV2LE22~32);
Selectivity category: A;
Utilization category: AC-3, AC-3e;
Suitable for isolation;
Rated frequency: 50/60Hz;
Trip class com.cqc.cms.component.word.CertiAnnexDataModel: 10A;
IP20;
Poles: 3P

Additional information (if necessary)

Date: Jun.01,2023

Signature: 谢肇煦
Xie ZhaoXu

CHINA QUALITY CERTIFICATION CENTRE
Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666
Fax: +86-10-83886282

website
http://www.cqc.com.cn

Name of the factory	Address of the factory
Schneider (Thailand) Limited	540 Soi 9 Bangpoo Industrial Estate, Sukhumvit Road, Muang District, Samutprakarn 10280

Additional information (if necessary)

Date: Jun.01,2023

Signature: 谢肇煦
Xie ZhaoXu