

Page 1 of 2

Certificate No: LR2440138TA Issue Date: 08/04/2024 Expiry Date: 07/04/2029

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer Schneider Electric Industries SAS

Address 31 Rue Pierre Mendes France, Eybens, Cedex 9, Grenoble, 38050, France

Place of Production Schneider Electric a.s.

Cizovska 447, Pisek, 397 01, Czech Republic

Place of Production Schneider Electric France

6-8 Rue du Bailly, Dijon Cedex, 21078, France

Place of Production Schneider Electric Thailand Co Ltd.

540 Soi 9 Bangpoo Industrial Estate, Sukhumvit Road, Muang, Samutprakarn,

10280, Thailand

Type circuit breakers

Description Manual Motor Controllers and Auxiliaries (GV Series)

Trade Name TeSys GV2

Application Marine and Offshore

Peter Huntley-Hawkins

Electrical & Control Technical Manager - UK & America to Lloyd's Register EMEA A member of the Lloyd's Register group

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Page 2 of 2

Certificate No: LR2440138TA Issue Date: 08/04/2024 Expiry Date: 07/04/2029

Type Approval Certificate

Specified Standard IEC/EN 60947-2, IEC/EN 60947-4-1, IEC/EN 60947-5-1

Ratings See Appendix

Additional Tests LR Test Specification No. 1 2015 ENV 1 and ENV 2

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

Previous Version: 94-00051(E6)

The Design Appraisal Document and its supplementary Type Approval Terms and Conditions form part of this Certificate.

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.