

**IEC****IECEE**

®

™

Ref. Certif. No.

CN72808

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

Auxiliary Contact Block

Name and address of the applicant

Schneider Electric Industries SAS  
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the manufacturer

Schneider Electric Industries SAS  
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the factory

Schneider Electric a. s.  
Cizovska 447- 39701 Pisek – Czech Republic*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

See the Appendix

Trademark (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

GVAN, GZ1AN, GVAD, GVAM;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2020;IEC 60947-5-1:2024

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2025CQC-122936

**CHINA QUALITY CERTIFICATION CENTRE CO., LTD.**

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Aug.14,2025

Signature:

谢肇煦

Xie ZhaoXu



GVAN, GZ1AN, GVAD, GVAM

Ui: 690V;

GVAN:

Uimp: 6kV;

Ith: 6A;

AC-15: Ue/Ie: 690V/0.6A;

DC-13: Ue/Ie: 240V/0.5A;

GZ1AN:

Uimp: 6kV;

Ith: 6A;

AC-15: Ue/Ie: 690V/0.6A;

DC-13: Ue/Ie: 240V/0.5A;

GVAD fault signaling contact:

Uimp: 4kV;

Ith: 2.5A;

AC-14: Ue/Ie: 240V/0.3A;

DC-13: Ue/Ie: 60V/0.15A;

GVAD instantaneous action contact:

Uimp: 6kV;

Ith: 6A;

AC-15: Ue/Ie: 690V/0.6A;

DC-13: Ue/Ie: 240V/0.5A;

GVAM:

Uimp: 4kV;

Ith: 2.5A;

AC-14: Ue/Ie: 240V/0.3A;

DC-13: Ue/Ie: 60V/0.15A;

IP20

Page 1 of 1

Additional information (if necessary)

Date:

Aug.14,2025

Signature:

谢肇煦

Xie ZhaoXu