

IEC

IECEE



Ref. Certif. No.

CN65907

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product

Thermal overload relay

Name and address of the applicant

Schneider Shanghai Industrial Control Co., Ltd.  
No.629 Suide Road, Putuo District, Shanghai, P.R.China

Name and address of the manufacturer

Schneider Electric Industries SAS  
35 Rue Joseph Monier, 92500 Rueil-Malmaison France

Name and address of the factory

Note: When more than one factory, please report on page 2

Schneider Shanghai Industrial Control Co., Ltd.  
No.629 Suide Road, Putuo District, Shanghai, P.R.China

Ratings and principal characteristics

Ui: 690V; Uimp: 6kV; Ue: AC690V; Ie: 0.10-0.16A, 0.16-0.25A,  
0.25-0.40A, 0.40-0.63A, 0.63-1A, 1-1.6A, 1.6-2.5A, 2.5-4A, 4-6A,  
5.5-8A, 7-10A, 9-13A, 12-18A, 16-24A, 23-32A, 30-38A; Tripping  
class: 10A; Pole: 3P; IP code: IP20 (from front face only); Auxiliary  
contacts (body): Ith: 5A; AC-15: 120V/3A, 500V/0.72A, 600V/0.12A,  
690V/0.09A; DC-13: 125V/0.22A, 440V/0.06A; 1NO1NC

Trademark (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

LRD01~35;

Additional information (if necessary may also be  
reported on page 2)A sample of the product was tested and found  
to be in conformity withIEC 60947-4-1:2018; IEC 60947-1:2007; IEC  
60947-1:2007/AMD1:2010; IEC 60947-1:2007/AMD2:2014As shown in the Test Report Ref. No. which  
forms part of this Certificate

00901-CB2024CQC-113149

## CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China  
Tel: +86-10-83886666 Fax: +86-10-83886282  
website: <http://www.cqc.com.cn>

Date: May.22,2024

Signature:

谢肇煦

Xie ZhaoXu

