



Declaration of Conformity

Issued by Manufacturer
Hoffman Enclosures, Inc.

2100 Hoffman Way, Anoka, Minnesota 55303-1745, U.S.A.

declare at our sole responsibility, that these devices are designed and constructed according to the fundamental safety and health requirements.

Enclosure Models: DAH****A, DAH****B, DAH*****C (Bulletin D85)
Equipment Description: Hoffman Electric Heaters (US Specific)
Enclosure Rating: CSA Certified
Enclosure Certification: CSA C22.2 No. 88-1958

PRODUCTS

CLASS - C287102 - HEATERS-Miscellaneous

Component panel board heaters, models as listed below:

<u>Model No</u>	<u>Volts</u>	<u>Watts</u>	<u>Hz</u>	<u>Amps</u>
D-AH1001A	115	100	50/60	0.9
D-AH1002A	230	140	50/60	0.6
D-AH2001A	115	200	50/60	1.7
D-AH2002A	230	200	50/60	0.9
D-AH4001B	115	400	50/60	3.3
D-AH4002B	230	400	50/60	1.7
D-AH8001B	115	800	50/60	6.5
D-AH8002B	230	800	50/60	3.3
D-AH1501A	115	150	50/60	1.3
D-AH13001C	115	1300	50/60	11.51
D-AH13002C	230	1300	50/60	5.7

Notes:

1. Certified as component only, where acceptability in the end product is to be determined by CSA Group.
2. These heaters are to be installed in a totally enclosed metal enclosure.

Applicable Standards: CSA C22.2 No. 88-1958 – Industrial Heating Equipment

Authorized by:

5/22/2020 (today's date)

Glen Kampa

Date

Senior Regulatory Engineer

Subject to Change Without Notice



Certificate of Compliance

Certificate: 1031710

Master Contract: 151630 (042186_C_000)

Project: 70193305

Date Issued: 2018-10-31

Issued to: Hoffinan Enclosures Inc.
2100 Hoffinan Way
Anoka, Minnesota 55303-1745
USA
Attention: Glen Kampa

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Varun Asokan*
Varun Asokan

PRODUCTS

CLASS - C287102 - HEATERS-Miscellaneous

Component panel board heaters, models as listed below:

<u>Model No</u>	<u>Volts</u>	<u>Watts</u>	<u>Hz</u>	<u>Amps</u>
D-AH1001A	115	100	50/60	0.9
D-AH1002A	230	140	50/60	0.6
D-AH2001A	115	200	50/60	1.7
D-AH2002A	230	200	50/60	0.9
D-AH4001B	115	400	50/60	3.3
D-AH4002B	230	400	50/60	1.7
D-AH8001B	115	800	50/60	6.5
D-AH8002B	230	800	50/60	3.3
D-AH1501A	115	150	50/60	1.3
D-AH13001C	115	1300	50/60	11.51
D-AH13002C	230	1300	50/60	5.7

Notes:

1. Certified as component only, where acceptability in the end product is to be determined by CSA Group.
2. These heaters are to be installed in a totally enclosed metal enclosure.



Certificate: 1031710
Project: 70193305

Master Contract: 151630
Date Issued: 2018-10-31

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 88-1958 - Industrial Heating Equipment