

CERTIFICATE OF COMPLIANCE

Certificate Number 20180523-E6294
Report Reference E6294-19830921
Issue Date 2018-MAY-23

Issued to: Schneider Electric USA, Inc.
1010 Airpark Center Dr
Nashville TN 37217

**This is to certify that
representative samples of**

COMPONENT - PANELBOARD AND SWITCHBOARD
ACCESSORIES


See Addendum Page For Models

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL67, Panelboards

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

The UL Recognized Component Mark generally consists of the manufacturer's identification and catalog
number, model number or other product designation as specified under "Marking" for the particular
Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products
that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark:
 may be used in conjunction with the required Recognized Marks. The Recognized Component Mark is
required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual
recognitions.

Recognized components are incomplete in certain constructional features or restricted in performance
capabilities and are intended for use as components of complete equipment submitted for investigation rather
than for direct separate installation in the field. The final acceptance of the component is dependent upon its
installation and use in complete equipment submitted to UL LLC.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20180523-E6294
Report Reference E6294-19830921
Issue Date 2018-MAY-23

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Component panelboard accessories - Circuit breaker, back-fed, hold-down, kits with the following Catalog Numbers.

Back-Fed Unit Hold-Down Kits

PK1MB and PK2MB

QO2DTIM

PK4MBX-LA, -HA (X denotes numbers 1 to 6)

PK4DT1MX-HA, LA, LAL (X denotes numbers 1 to 6)

HOM4RKX-HA, LA (X denotes numbers 1 to 6)

HOM5RK

PK5RK

ILLS. and Figs.

ILLS. 8 and 9

Fig. 1

ILLS. 10 and 11

ILLS. 1, 4, 10, 11

ILLS. 10 and 11

ILLS. 13 and 14

ILLS. 15, 16, and 17

Generator Interlock Kits

QOM2, 150-225A Main Breaker Devices:

Indoor Devices – QOCGK2 and HOMCGK2

Outdoor Devices - QORBGK2 and HOMRBGK2

Indoor & Outdoor Devices – QOCRBGK3

QOM1, 100-125A Main Breaker Devices:

Indoor & Outdoor Devices – QOCRBGK1, HOMCRBGK1

Circuit Breaker Type QO, 2 poles, 60A max:

Indoor devices – QOCGKX

Circuit Breaker Type HOM, 2 poles, 60A max:

Indoor devices – HOMCGKX

Fig 2

Fig 3

Fig 3

Fig 4, 5

Fig 6, 7, 8


May include suffix "C" indicating the kits are provided in Clamshell packaging.

Suffix letters may be added to catalog number to designate right or left orientation or for optional additional retaining test.

Mechanical Interlock Attachment, QO2DTI, is included in Hold-down kits denoted with DTIM in catalog numbers and is intended to be mounted on circuit breakers installed in a panelboard for the purpose of interlocking main and auxiliary supply in the off or on position.

Mechanical Interlock Attachment, Cat. No. QO2DTIM, includes hold-down kit Cat. No. PK2MB. See ILL. 12 for installation instructions.

Service Entrance Barrier - The Back-Fed unit hold-down kits, Cat. Nos. PK4M2LA & PK4MB2HA, are intended to be mounted on circuit breakers type QO, QOA in conjunction with a panelboard marked as suitable to be used as service entrance.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

