

## CERTIFICATE OF COMPLIANCE

**CERTIFICATE NUMBER:** 161002-E181374A

**ISSUE DATE:** October 16, 2002

**Page 1 of 1**

**Issued to:** Square D Company  
3700 6th Street S.W. - PO Box 3069  
Cedar Rapids, IA. 52404

**Report Reference:** E181374, February 4, 2002


**This is to Certify that  
representative samples of:** Molded Case Circuit Breakers with equipment ground fault protection, type  
HOM, series 1, two pole

**Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s)  
indicated on this Certificate.**

**Standard(s) for Safety:** UL 489, Molded Case Circuit Breakers, Molded Case Switches and Circuit Breaker Enclosures.  
UL 1053, Ground-Fault Sensing and Relaying Equipment.  
CSA C22.2 No. 5-02, Molded Case Circuit Breakers, Molded Case Switches and Circuit Breaker Enclosures.  
CAN/CSA - C22.2 No. 144-M91, Ground Fault Circuit Interruptors.

**Additional Information:** These are two pole circuit breakers with ground fault protection and rated  
15A to 50A single phase, 120/240 Vac, 60 Hz, 10kA current interrupting  
rating. Ground fault tripping level is 28 to 32 mA.

**Only those products bearing the UL Listing Mark for the US and Canada should be considered  
as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements  
for US and Canada.**

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word  
"LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the  
appropriate UL Directory.

### **LOOK FOR THE UL LISTING MARK ON THE PRODUCT**

**Engineer:**  
Lawrence R. Smith, Lead Engineering Assoc.  
Underwriters Laboratories Inc.

**Review Engineer:**  
Antonio Romanacce, Engineering Team Leader  
Underwriters Laboratories Inc.

