

# Certificate of Compliance

**Certificate:** 2280972

**Master Contract:** 214768

**Project:** 2280972

**Date Issued:** 2010-03-02

**Issued to:** Schneider Electric USA, Inc.  
Square D  
Raleigh (Knightdale) Plant 8001  
Knightdale Blvd.  
Knightdale, NC 27545  
USA

**Attention:** Mrs. Nancy Gunderson

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** Daphane Flemings

## PRODUCTS

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

- Time delay relays, Models 9050JCK1 through 9050JCK5, followed by letters and/or numbers, open type with dust cover, rated input 12V ac/dc, 24V ac/dc, 48V ac/dc, 120V ac/dc, 240V ac; contacts 10A general purpose at 240V ac, 10A resistive at 28V dc; ½ hp, 240V ac; 1/3 hp, 120V ac; B300; R300.
- Time delay relays, Models 9050JCK6 and 9050JCK7, followed by letters and/or numbers, open type with dust cover, rated input 12V ac/dc, 24V ac/dc, 48V ac/dc, 120V ac/dc, 240V ac; contacts 10A general purpose at 240V ac; 10A resistive at 28V dc; ½ hp, 240V ac; 1/3 hp, 120V ac; B300; R300.

## APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 14 – Industrial Control Equipment

UL Std No. 508 – Industrial Control Equipment

## MARKINGS

Listee's name and/or CSA file number 214768, model designation, complete electrical rating in volts, hertz, hp, amps, serial number or date coding, and the CSA Mark appear in a permanent manner on each unit.