

Northbrook, Illinois • (847) 272-8800 Melville, New York • (516) 271-6200 Santa Clara, California • (408) 985-2400

Research Triangle Park, North Carolina • (919) 549-1400

Camas, Washington • (360) 817-5500

CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: ISSUE DATE: 210497-E84967B April 21, 1997

Issued to:

Square D Company 3700 6th Street S. W.

Cedar Rapids, IA 52404-3069, USA

Report Reference:

E84967, November 10, 1989

This is to Certify that representative samples of:

Molded Case Circuit Breakers

Type HOM Series 1

Have been investigated by Underwriters Laboratories Inc. in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 489, Molded Case Circuit Breakers and Circuit

Breaker Enclosures

Additional Information:

These are one and two pole circuit breakers, rated from 15A through

50A, 1 pole and 15A through 70A, 2 pole. Current Interrupting Rating is as follows: 10,000A, 120/240 Vac, 1phase, 50/60 Hz.

Uses wires rated as follows:

60 or 75 Deg. C for 15-30A and 75 Deg. C only for 35-70A

Notes: May be marked"Listed HACR Type".

15 & 20A, 1 pole breakers may be marked "SWD".

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The ULListing Mark generally includes four elements as follows: the name "Underwriters Laboratories Inc." in various forms and type styles, or abbreviations such as "Und. Lab. Inc.", or the symbol "UL in a circle" (4); the word "Listed"; a control number (may be alphanumeric) assigned by UL; and the product or category name (product identifier), as indicated in the appropriate UL Directory.

OOKTOR HILLLISHING MARK ON THE PRODUCT

Engineer:

Review Engineer: UtKaram Underwriters Laboratories Inc.

Underwriters Laboratories Inc.

Art Karamagianis

Lawrence Smith