Northbrook, Illinois • (847) 272–8800

Melville, New York • (516) 271–6200

Santa Clara, California • (408) 985–2400

Research Triangle Park,
North Carolina • (919) 549–1400

Camas, Washington • (360) 817–5500

(UL) Underwriters Laboratories Inc.®

CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER:

260401-E48340A

ISSUE DATE:

April 26, 2001

Page 1 of 1

Issued to:

Square D Company 3700 6th Street S.W.

Cedar Rapids, IA 52404-3069, USA

Report Reference:

E48340, February 1, 1988

This is to Certify that

representative samples of:

Molded Case Circuit Breakers and Ground Fault Interrupter

Type HOM Series 1

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 489, Molded Case Circuit Breakers and Circuit Breaker Enclosures

Additional Information:

These are one pole circuit breakers and ground fault interrupters, class "A" rated

15A and 20A

Current Interrupting Rating is as follows:

10,000A, 120Vac, 1 phase, 60 Hz. Uses wires rated as follows:

60/75 Deg.C.

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle: with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

LOOK FOR THE ULLISTING MARK ON THE PRODUCT

Engineer: Lawrence R. S.

Lawrence R. Smith, Staff Eng. Associate

Underwriters Laboratories Inc.

Review Engineer:

Bob Hames, Sr. Staff Engineer

Underwriters Laboratories Inc.