

Northbrook, Illinois • (847) 272-8800

Melville, New York • (516) 271-6200

Santa Clara, California • (408) 985-2400

Research Triangle Park,
North Carolina • (919) 549-1400

Camas, Washington • (360) 817-5500

CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: ISSUE DATE:

210497-E84967C April 21, 1997

Issued to:

Square D Company 3700 6th Street S. W.

Cedar Rapids, IA 52404-3069, USA

Report Reference:

E84967, March 17, 1992

This is to Certify that representative samples of:

Molded Case Circuit Breakers

Type HOM Series 1

Have been investigated by Underwriters Laboratories Inc. in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 489, Molded Case Circuit Breakers and Circuit

Breaker Enclosures

Additional Information:

These are two pole circuit breakers, rated from 80A through

100A.

Current Interrupting Rating is as follows: 10,000A, 120/240 Vac, 1phase, 50/60 Hz.

Uses wires rated as follows:

75 Deg. C only.

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The ULListing Mark generally includes four elements as follows: the name "Underwriters Laboratories Inc." in various forms and type styles, or abbreviations such as "Und. Lab. Inc.", or the symbol "UL in a circle" - (1); the word "Listed"; a control number (may be alphanumeric) assigned by UL; and the product or category name (product identifier), as indicated in the appropriate UL Directory.

FOR KICK THEFT LISTING MARK ON THE PRODUCT

Engineer:

Underwriters Laboratories Inc.

Review Engineer:

: Jeffrey Hedaka

Lawrence Smith

Underwriters Laboratories Inc

Jeffrey Hidaka

2000-44L 3/97