



Certificate of Compliance

Certificate: 1173851 (LR 92886-92)

Master Contract: 153555

Project: 70059092

Date Issued: 2016-01-06

Issued to: Schneider Electric USA, Inc.
Square D
3700 6th St SW
Cedar Rapids, Iowa 52404
USA

Attention: Manuel Salinas

The products listed below are eligible to bear the CSA Mark shown



Issued by: Ronald Tateishi
Ronald Tateishi

PRODUCTS

CLASS 1432 01 - CIRCUIT BREAKERS - Moulded Case Type

Moulded case circuit breakers, Type QOU, Series 1, 3-pole, 70-100A, 240V ac max, 60V dc max.

Notes:

1. These circuit breakers are suitable for use with copper and aluminum conductors.
2. These circuit breakers are suitable for reversed line and load connectors.
3. These circuit breakers may be provided with shunt trip, auxiliary switch and bell alarm accessories.
4. These circuit breakers may be marked with interrupting ratings in maximum RMS Symmetrical Amperes as follows:

<u>Breaker</u> <u>A</u>	<u>Rating</u> <u>V</u>	<u>Poles</u>	<u>Marked Interrupting Rating</u> <u>Maximum RMS, Symmetrical A</u>
70-100	240V ac	3	10,000
70-100	60V dc	3	5,000



Certificate: 1173851 (LR 92886-92)

Project: 70059092

Master Contract: 153555

Date Issued: 2016-01-06

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures



Supplement to Certificate of Compliance

Certificate: 1173851 (LR 92886-92)

Master Contract: 153555

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70059092	2016-01-06	Addition of an alternate construction of the arc stack.
2700224	2014-02-06	Addition of an alternate construction of the arc stack.
2646831	2013-07-22	Revised construction of the toggle spring.
2465407	2011-10-12	Revised construction of the arc stack.
1978902	2007-12-13	Addition of a new arc chute/plate on the 80-100A, 3-pole circuit breakers.
1844523	2006-10-24	Revised arc stack construction.