



Underwriters Laboratories Inc.®

Northbrook, Illinois • (708) 272-8800
Melville, New York • (516) 271-6200
Santa Clara, California • (408) 985-2400
Research Triangle Park,
North Carolina • (919) 549-1400

CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 311095 - E84967A
ISSUE DATE: October 31, 1995

Issued to: Square D Company
3700 6th Street S.W.
Cedar Rapids, IA 52404, USA

Report Reference: E84967 - December 30, 1970

This is to Certify that representative samples of: Molded-Case Circuit Breakers, Type QO and QOB with Catalog Number Prefix QO or QOB

Have been investigated by Underwriters Laboratories Inc. in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 489, Molded-Case Circuit Breakers and Circuit Breaker Enclosures

Additional Information:

These are one, two & three pole HACR Type circuit breakers with the following ratings:
- one & two pole rated 10 thru 70 A maximum, single phase, 120/240 V, 60 Hz
Current Interrupting Rating is 10kA, 120/240 V ac and 5kA, 48 V dc, AIR
- three pole rated 10 thru 60 A maximum, three phase, 240 V ac, 60 Hz
Current Interrupting Rating is 10kA, 240 V ac and 5kA, 48 V dc, AIR

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes four elements as follows: the name "Underwriters Laboratories Inc." in various forms and type styles, or abbreviations such as "Und. Lab. Inc.", or the symbol "UL in a circle" - ; the word "Listed"; a control number (may be alphanumeric) assigned by UL; and, the product or category name (product identifier) as indicated in the appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer:
Underwriters Laboratories Inc.
Mark R. Barron

Review Engineer:
Underwriters Laboratories Inc.
Jolanta M. Wroblewska