



# Certificate of Compliance

**Certificate:** 1160039 **Master Contract:** 153555  
**Project:** 80152231 **Date Issued:** 01/13/2023  
**Issued to:** Schneider Electric USA, Inc. Square D  
3700 6th St SW  
Cedar Rapids, Iowa 52404  
United States  
**Attention:** Manuel Salinas

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** Steven Montminy  
Steven Montminy

## PRODUCTS

C143201 CIRCUIT BREAKERS - Moulded Case Type

**Circuit breakers, Types QO and QOB, thermal magnetic trip, uncompensated, one-and two-pole, 10-70A, 240V ac max, two-poles 10-60A, 48V dc max and three-pole, 10-60A, 240V ac max.**

Models	Pole(s)	Current (A)	Voltage (VAC max)	Voltage (VDC max)
QO, QOB	1 and 2	10-70	240	
	2	10-60		48
	3	10-60	240	

### Notes:

1. The mechanism is trip-free of the handle, which assumes a mid-position between on and off upon automatic tripping.
2. These circuit breakers are suitable for use with copper and aluminum conductors.
3. These circuit breakers may be provided with shunt trip, auxiliary and bell alarm accessories.
4. The 15 and 20 A, 1-pole circuit breakers are suitable for switching fluorescent lighting loads and may be marked "SWD".
5. Types QO and QOB 15-50 A, 1 and 2 pole and 15-30 A, 3 pole non-quick trip breakers may be marked "HID" and are intended to switch 240 V ac high intensity discharge lighting systems.



**Certificate:** 1160039

**Master Contract:** 153555

**Project:** 80152231

**Date Issued:** 01/13/2023

---

**APPLICABLE REQUIREMENTS**

CSA C22.2 NO. 5-16 - Molded-case circuit breakers, molded-case switches and circuit-breaker enclosures (Tri-national standard with UL 489 and NMX-J-266-ANCE-2016)



**Certificate:** 1160039

**Project:** 80152231

**Master Contract:** 153555

**Date Issued:** 01/13/2023

Notes:

Products certified under Class C143201 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). [www.scc.ca](http://www.scc.ca)

