

CERTIFICATE OF COMPLIANCE

Certificate Number 20171113 – E2875
Report Reference E2875 – 19620322
Issue Date 2017-NOVEMBER-13

Issued to: SCHNEIDER ELECTRIC USA, INC.
1010 Airpark Center Dr
Nashville, TN 37217 USA

This is to certify that representative samples of Switches, Enclosed
Enclosed switches, 30A, Model(s) 92251, 92251-F, 92351, 92351-F, 92442, 92451, 92452.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ANSI/UL 98, "Enclosed and Dead-Front Switches."
CAN/CSA-C22.2 No. 4 (2004), "Enclosed and Dead-Front Switches."

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

