Northbrook, Illinois • (847) 272-8800 Meiville, New York • (631) 271-6200 Santa Clara, California • (408) 985-2400 Research Triangle Park, North Carolina • (919) 549-1400 Camas, Washington • (360) 817-5500



ERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 101000-E2875D

ISSUE DATE:

October 10, 2000

Page 1 of 3

Issued to:

Square D Company

1601 Mercer Road

Lexington, KY. 40511 USA

Report Reference:

E2875, February 9, 1972

This is to Certify that

Enclosed switches, types D121, D221, D321, DU221, DU321, DU222 & representative samples of:

DU322, suitable for use as service equipment. catalog numbers may have

suffix letters.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 98, Enclosed Switches

Additional Information:

See Addendum

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle: W with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product casegory name (product identifier) as indicated in the appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer:

Review Engineer:

Underwriters Laboratories Inc.

Underwriters Laboratories Inc.

A not-for-profit organization dedicated to public safety and committed to quality service

Northbrook, Illinois • (847) 272-8800 Melville, New York • (631) 271-6200 Santa Clara, California • (408) 985-2400 Research Triangle Park, North Carolina • (919) 549 1400 Camas, Washington • (360) 817-5500

Underwriters Laboratories Inc.®

CERTIFICATE OF COMPLIANCE - ADDENDUM

CERTIFICATE NUMBER: 101000-E2875D

Page 2 of 3

ISSUE DATE:

October 10, 2000

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

RATINGS

Current - 30 A and 60 A Voltage - 240 V ac maximum

Short Circuit

When used with Class R fuses with Kit No. DRK-30 properly installed, fusible switches are suitable for use on circuits capable of delivering not more than 100,000 rms symmetrical amperes.

Unfused switches are sutiable for use on circuits delivering not more than 100,000 rms symmetrical amperes for 30 A switches, and 50,000 for 60 A switches, when protected by fuses (circuit breaker) rated not more than the switch.

Tom Skibbs

Underwriters Laboratories Inc.

Review Engineer:

Underwriters Laboratories Inc.

A not-for-profit organization dedicated to public safety and committed to quality service

Northbrook, Illinois • (847) 272-8800 Melville, New York • (631) 271-6200 Santa Clara, California • (408) 985-2400 Research Triangle Park, North Carolina • (919) 549-1400 Camas, Washington • (360) 817-5500



CERTIFICATE OF COMPLIANCE - ADDENDUM

CERTIFICATE NUMBER: 101000-E2875D

Page 3 of 3

ISSUE DATE:

October 10, 2000

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

				Horsepower (+indicates maximum rat			
			Current	Alternating			Direct
			Voltage	120		240	125
			Phase	1	11	3	
	Amps	Volts(max)	Wires	2	2	3	2
D121-N	30	120ac/125dc		1.5, 2+			2, 3+
D221	30	240ac			1.5, 3+		
D221-N	30	240ac			1.5, 3+	3, 7.5	+
D321	30	240ac			1.5, 3+	3, 7.5	+
D321-N	30	240ac				3, 7.5	+
DU221	30	240ac			3		
DLJ321	30	240ac			3	7.5	
DU322	30	240ac			10	15	
DU222	30	240ac			10		

Engineer:

Tom Skibbs

Underwriters Laboratories Inc.

Review Engineer: Jake Killinger Underwriters Laboratories Inc.