Northbrook, Illinois • (847) 272-8800 Melville, New York • (631) 271-6200 Santa Clara, California • (408) 985-2400 Research Triangle Park, North Carolina • (919) 549-1400 Camas, Washington • (360) 817-5500



CERTIFICATE NUMBER:

101000-E2875G

ISSUE DATE:

October 10, 2000

Page 1 of 3

Issued to:

Square D Company

1601 Mercer Road

Lexington, KY. 40511 USA

Report Reference:

E2875, July 6, 1990

This is to Certify that

representative samples of: Enclosed switches, types D222 & D322, suitable for use as service

equipment. Catalog numbers may have suffix letters.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 98, Enclosed Switches

Additional Information:

See Addendum

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle: (4) with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

OOK FOR THE ULLISTING MARK ON THE PRODUCT

Engineer:

Under writers Laboratories Inc.

Review Engineer:

Under writers Laboratories Inc.

A not-for-profit organization dedicated to public safety and committed to quality service

Northbrook, Illinois • (847) 272-8800 Melville, New York • (631) 271-6200 Santa Clara, California • (408) 985-2400 Research Triangle Park, North Carolina • (919) 549 1400 Camas, Washington • (360) 817-5500

Underwriters Laboratories Inc.®

CERTIFICATE OF COMPLIANCE - ADDENDUM

CERTIFICATE NUMBER: 101000-E2875G

Page 2 of 3

ISSUE DATE:

October 10, 2000

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

RATINGS

Current - 60 A maximum Voltage - 240 V ac maximum

Short Circuit

When used with Class R fuses with Kit No. HRK30H properly installed, fusible switches are suitable for use on circuits capable of delivering not more than 100,000 rms symmetrical amperes.

When used with Class H or K fuses, fusible switches are suitable for use on circuits capable of delivering not more than 10,000 symmetrical amperes.

Unfused switches are suitable for use on circuits capable of delivering not more than

(A) 10,000 rms symmetrical amperes when protected by Class H or K fuses or

(B) 100,000 rms symmetrical amperes when protected by Class J, T, or R fuses.

Engineer:

Tom Skibbs

Underwriters Laboratories Inc.

Review Engineer: Jake Killinger / Wh

Underwriters Laboratories Inc.

A not-for-profit organization dodicated to public safety and committed to quality service

Northbrook, Illinois • (847) 272-8800 Melville. New York • (631) 271-6200 Santa Clara, California • (408) 985-2400 Research Triangle Park, North Carolina • (919) 549-1400 Camas, Washington • (360) 817-5500

Underwriters Laboratories Inc.®

CERTIFICATE OF COMPLIANCE - ADDENDUM

CERTIFICATE NUMBER: 101000-E2875G

Page 3 of 3

ISSUE DATE:

October 10, 2000

This is to verify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Horespower Ratings (* indicates grounded B phase, 2-pole with neutral)

		TITEMENTOS MICE	
Cat. No.	Phases_	Standard	Maximum
D222	1	3	10
D322	1	3	10
D222	3	<i>7.</i> 5*	15
D322	3	7.5	15

Engineer:

Tom Skibbs

Underwriters Laboratories Inc.

Review Engineer:

Underwriters Laboratories Inc.

A not-for-profit organization dedicated to public safety and committed to quality service