

Northbrook, Illinois • (847) 272-8800

Melville, New York • (516) 271-6200

Santa Clara, California • (408) 985-2400

Research Triangle Park

Research Triangle Park, North Carolina • (919) 549–1400

Camas, Washington • (360) 817-5500

CERTIFICATE OF COMPLIANCE

CERTIFICATENUMBER:

030699-E181374 June 3,1999

ISSUE DATE:

Company

Issued to:

Square D Company 3700 6th Street S. W.

Cedar Rapids, IA 52404-3069, USA

Report Reference:

E181374, October 12,1995

This is to Certify that representative samples of:

Molded Case Circuit Breakers with equipment ground

Fault protection, Type QO and QOB, Series 2.

Have been investigated by Underwriters Laboratories Inc. in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 489, Molded Case Circuit Breakers and Circuit

Breaker Enclosures

UL 1053, Ground Fault Sensing and Relaying Equipment

Additional Information:

The product includes two switched poles and an unswitched pole and is rated 120/240 V, 15-60 A, 60 Hz. Interrupting Ratings: 10 kA, 120/240 V, 60 Hz. These products are intended to be installed in a Listed panelboard or other suitable enclosure, to provide overcurrent protection of conductors and equipment ground fault

protection set at 30 mA.

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The ULListing Mark generally includes four elements as follows: the name "Underwriters Laboratories Inc." in various forms and type styles, or abbreviations such as "Und. Lab. Inc.", or the symbol "UL in a circle" - (1); the word "Listed"; a control number (may be alphanumeric) assigned by UL; and the product or category name (product identifier), as indicated in the appropriate UL Directory.

LOOK FOR THE ULLISTING MARK ON THE PRODUCT

Engineer: antonia Kommance

Underwriters Laboratories Inc. Antonio Romanacce Review Engineer:

rs Laboratories inc.

2000-44L 3/97

L:\LRS\CLIENTS\SQDSTUFF\CERTCOMP \ cercompqo260