

Certificate of Compliance

Certificate Number **20110328 – E84905**
Report Reference **E84905, 1996 May 03**
Issue Date **2011 March 28**

Page 1 of 2



Issued to: **SCHNEIDER ELECTRIC USA INC / SQUARE D CO**

1010 AIRPARK CENTER DR
NASHVILLE, TN 37217 USA

*This is to certify that
representative samples of*

**Circuit Breakers, Molded Case and Circuit-breaker
Enclosures**

Model Descriptions: Molded case circuit breakers, Catalog number prefix ED, EG, EJ and EK Series 3. The 480Y/277 V product ranges in amperes from 15 A to 125 A and the 600Y/347 V product ranges in amperes from 15 A to 110 A.

*Have been investigated by Underwriters Laboratories Inc.® in accordance with
the Standard(s) indicated on this Certificate.*

Standard(s) for Safety: **The basic standard used to investigate products in this category is ANSI/UL 489, "Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures" and CAN/CSA-C22.2 No. 5 (2002), "Molded-Case Circuit Breakers, Molded-Case Switches and Circuit Breaker Enclosures."**

Additional Information: **See Addendum.**
(Cont.)

Certificate of Compliance



Additional Information: **INTERRUPTING RATINGS:**

Frame And Interrupting Rating	Poles	A	Current Interrupting Rating		
			120	240, 277 V	347 V
ED	1	15-70	25,000	18,000	14,000
EG	1	15-70	65,000	35,000	18,000
EJ	1	15-70	100,000	65,000	25,000
EK	1	15-30	100,000	65,000	65,000

Frame And Interrupting Rating	Poles	A	Current Interrupting Rating		
			240 v(+)	480Y/277	600Y/347
ED	2, 3	15-110	25,000	18,000	14,000
EG	2, 3	15-110	65,000	35,000	18,000
EJ	2, 3	15-110	100,000	65,000	25,000

ED	2, 3	125	25,000	18,000
EG	2, 3	125	65,000	35,000
EJ	2, 3	125	100,000	65,000

(+) - Two pole construction suitable for 1ph-3ph rating. Carries an interrupting rating equivalent to that Listed in the 480Y/277 column.

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers; the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

William R. Carney
Director, North American Certification Programs

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.

For questions, please contact a local UL Customer Service Representative at <http://www.ul.com/global/eng/pages/corporate/contactus/>