


CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 161002-E181374B**ISSUE DATE: October 16, 2002****Page 1 of 1****Issued to:** Square D Company
3700 6th Street S.W. - PO Box 3069
Cedar Rapids, IA. 52404**Report Reference: E181374, February 1, 2002****This is to Certify that
representative samples of:** Molded Case Circuit Breakers with equipment ground fault protection type
HOM, series 1, one pole.**Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s)
indicated on this Certificate.****Standard(s) for Safety:** UL 489, Molded Case Circuit Breakers, Molded Case Switches and Circuit Breaker Enclosures.
UL 1053, Ground-Fault Sensing and Relaying Equipment.
CSA C22.2 No. 5-02, Molded Case Circuit Breakers, Molded Case Switches and Circuit Breaker Enclosures.
CAN/CSA - C22.2 No. 144-M91, Ground Fault Circuit Interruptors.**Additional Information:** These are one pole circuit breakers with ground fault protection, rated 15 to 20
amp, single phase, 120 Vac, 60Hz, 10kA current interrupting rating. Ground
fault tripping level is 28 to 32 mA.**Only those products bearing the UL Listing Mark for the US and Canada should be considered
as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements
for US and Canada.**

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT**Engineer:**
Lawrence R. Smith, Lead Engineering Assoc.
Underwriters Laboratories Inc.**Review Engineer:**
Antonio Romanacce, Engineering Team Leader
Underwriters Laboratories Inc.