

# Certificate of Compliance

Certificate Number E181374-20050816  
Report Reference E181374, August 16, 2005  
Issue Date 2005 August 29

Page 1 of 1



**Underwriters  
Laboratories Inc.®**

*Issued to:* **Square D Co.**  
3700 6th Street S.W.  
Cedar Rapids, IA. 52404

*This is to certify that  
representative samples of*

**Circuit Breaker Equipment with Ground Fault Protection**  
Catalog Number Prefix ED, EG & EJ Series 1.

*Have been investigated by Underwriters Laboratories Inc.® in  
accordance with the Standard(s) indicated on this Certificate.*

*Standard(s) for Safety:*


UL 1053 Ground-Fault Sensing and Relaying Equipment  
UL 489 Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-  
Breaker Enclosures

*Additional Information:*

Ratings: 277 v, 15-50A, 28-32mA trip level for ground fault sensing and relay module.

| Interrupting Ratings: | Frame | Current Interrupting Rating |
|-----------------------|-------|-----------------------------|
|                       | ED    | 18,000                      |
|                       | EG    | 35,000                      |
|                       | EJ    | 65,000                      |

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

**Look for the UL Listing Mark on the product**

Issued by: *Benny Jackson*  
Benny Jackson, Assoc. Project Engineer  
Underwriters Laboratories Inc.

Reviewed by: *Antonio Romanacce*  
Antonio Romanacce, Manager  
Underwriters Laboratories Inc.