



Certificate of Compliance

Certificate: 1701881 (LR 29971)

Master Contract: 153555

Project: 2530796

Date Issued: June 8, 2012

Issued to: Schneider Electric USA, Inc.

Square D
3700 6th St SW
Cedar Rapids, IA 52404
USA
Attention: Jan Harper

The products listed below are eligible to bear the CSA Mark shown



R. Tateishi

Issued by: R. Tateishi, P. Eng.

PRODUCTS

CLASS 1451 01 - GROUND FAULT DEVICES - Circuit Interrupters

Combined circuit breaker and ground fault interrupter, 30mA sensitivity, Cat. No. Prefixes ED, EG and EJ with suffix EPD, Series 1, 1-pole, 15-50A, 277V ac.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures

CAN/CSA-C22.2 No. 144 - Ground Fault Circuit Interrupters