



# Certificate of Compliance

**Certificate:** 1542878 (LR 7551)

**Master Contract:** 153555

**Project:** 70021092

**Date Issued:** January 21, 2015

**Issued to:** Schneider Electric USA, Inc.

Square D  
3700 6th St SW  
Cedar Rapids, IA 52404  
USA  
Attention: Jerry Beasler

*The products listed below are eligible to bear the CSA Mark shown*



*Ron Tateishi*

**Issued by:** Ron Tateishi

## **PRODUCTS**

**CLASS 1432 01 - CIRCUIT BREAKERS - Moulded Case Type**

Moulded case circuit breakers, Powerpact M with suffix G and J, 2- and 3-pole, 800A, 600V ac max.

## **APPLICABLE REQUIREMENTS**

CSA Standard C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures

