



产品认证证书

证书编号：CQC2014010303716729

申请人名称及地址

施耐德电气（中国）有限公司上海分公司
上海市普陀区绥德路 669 号

制造商名称及地址

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

生产企业名称及地址

PT. Schneider Electric Manufacturing Batam(V049531)
Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka
Kuning Kel.Muka Kuning Kec. Sungai Beduk - Batam, Indonesia

产品名称和系列、规格、型号

时间继电器

REXL: Ui:250V;Uimp:4kV;AC-12:230V/5A; Ith:5A; IP20; 详细型号解释见附件

产品标准和技术要求

GB/T 14048.5-2017

认证模式

型式试验+获证后监督

上述产品符合 CQC11-462142-2019 认证规则的要求，特发此证。

发证日期：2020 年 08 月 25 日 有效期至：2024 年 05 月 27 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

经中国合格评定国家认可委员会认可 CNAS C001-P

主任：_____

陆楠



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

C 0372612



PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC2014010303716729

NAME AND ADDRESS OF THE APPLICANT

Schneider Electric (China) Co. Ltd. Shanghai Branch
No. 669, Suide Road, Putuo District, Shanghai, China

NAME AND ADDRESS OF THE MANUFACTURER

Schneider Electric Industries SAS
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

NAME AND ADDRESS OF THE FACTORY

PT. Schneider Electric Manufacturing Batam (V049531)
Jl Beringin Lot 4, Lot 208, Lot 1, Lot 15, Lot 16, DAN Lot 16A BIP Muka Kuning Kel.Muka Kuning Kec. Sungai
Beduk – Batam, Indonesia

PRODUCT NAME, MODEL AND SPECIFICATION

Timing Relay
REXL: Ui:250V;Uimp:4kV;AC-12:230V/5A; Ith:5A; IP20;

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification
rules of CQC11-462142-2019 .

Valid from: Aug.25,2020 Valid until: May.27,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing
certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

President: _____

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China
<http://www.cqc.com.cn>

C 0372612



产品认证证书

附录

第 1 页 共 1 页

证书编号: CQC2014010303716729

纸号: 372612

型号解释:

REXL	2	TM	B7	
I	II	III	IV	

I 产品系列 Product Rang	REXL: 时间继电器 Timing Relay
II: 继电器触点类型 Relay contact type	- 2: 双极双掷开关 two pole double throw (2PDT) - 4: 四极双掷开关 four pole double throw (4PDT)
III: TM	功能 Function A
IV: 输入电压 Input Voltage (50/60 Hz)	-B7: 24V ac -BD: 24V dc -F7: 110 -127 V ac -JD: 12V dc -P7: 230-240 V ac

注: 此附录与证书同时使用时有效。

主任: 陆楠



中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>