



Ref. Certif. No.

SG PSB-IT-00306

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Connector (Relay socket)
Name and address of the applicant	Schneider Electric Asia Pte Ltd 50 Kallang Ave Singapore 339505 SINGAPORE
Name and address of the manufacturer	Schneider Electric Industries SAS 35 rue Joseph Monier, 92500 Rueil Malmaison, FRANCE
Name and address of the factory	Schneider Electric (China) Co., Ltd. (SSVF) – (Supply Chain Operation) 669 Sui De Road, Pu Tuo District, 200331 Shanghai, PEOPLE'S REPUBLIC OF CHINA
Ratings and principal characteristics	Rated current (At 55°C): Seen below table 1 Rated voltage: 250VAC/DC Rated insulation voltage: 250V Overvoltage category: III Pollution degree: 3 Number of poles: Seen below table 1 IP code: IP20 (After proper mated) Temperature range (LLT-ULT): -40°C to +145°C Type of terminal: See below table 1
Model/type Ref.	RXZE2M114, RXZE2M114M, RXZE2S108M, RXZE2S111M, RXZE2S114M, RXZE14P
Additional information (if necessary)	Also complies with Clause 14.5 of IEC 61810-1:2015.
A sample of the product was tested and found to be in conformity with	IEC 61984:2008
as shown in the Test Report Ref. No. which forms part of this certificate	085-223139601-000

Page 1 of 3

This CB Test Certificate is issued by the National Certification Body

CBS 122434 0001 Rev. 00

Date, 2023-09-12

( Frank Zhu )

TÜV SÜD PSB Pte Ltd 15 International Business Park TÜV SÜD @ IBP Singapore 609937



PSB Singapore

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Trademark / Brand (Image)




Ratings and principal characteristics (continued)

Connectable conductors:	Flexible, solid
Wire cross-section area:	Seen below table 2
With or without breaking capacity:	Without (COC)
Number of operating cycles/mechanical endurance:	500

Table 1: Different information for all models

Model	Rated current	Number of poles for relay contact part	Number of poles for relay coil part	Type of terminal	Remark
RXZE2M114	10A	4	1	Screw-type	Mate with RXM2 and RXM4 series relay. The largest current for RXM2 series relay with sockets is 10A.
RXZE2M114M	10A	4	1	Screw-type	
RXZE2S108M	12A	2	1	Screw-type	Mate with RXM2 series relay
RXZE2S111M	10A	3	1	Screw-type	Mate with RXM3 series relay
RXZE2S114M	10A	4	1	Screw-type	Mate with RXM2 and RXM4 series relay. The largest current for RXM2 series relay with RXZE2S114M is 10A.
RXZE14P	12A (2CO)/ 6A (4CO)	4	1	Screwless-type	

Page 2 of 3

This CB Test Certificate is issued by the National Certification Body

CBS 122434 0001 Rev. 00

Date, 2023-09-12



( Frank Zhu )



## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Table 2: The connected wire for the relay sockets

Model	Number of conductors connected in one hole of a terminal	Wire cross section range for prepared flexible conductors	Wire cross section range for unprepared solid conductors
RXZE2M114	1	0.34-1.0mm <sup>2</sup> (22-17AWG)	0.5-1.5mm <sup>2</sup> (20-16AWG)
	2	0.34-1.0mm <sup>2</sup> (22-17AWG)	0.5-1.5mm <sup>2</sup> (20-16AWG)
RXZE2M114M RXZE2S108M RXZE2S111M RXZE2S114M	1	0.34-2.5mm <sup>2</sup> (22-14AWG)	0.5-2.5mm <sup>2</sup> (20-14AWG)
	2	0.34-1.0mm <sup>2</sup> (22-17AWG)	0.5-1.5mm <sup>2</sup> (20-16AWG)
RXZE14P	1	0.5-1.5mm <sup>2</sup> (20-16AWG)	0.5-1.5mm <sup>2</sup> (20-16AWG)



( Frank Zhu )

