



# Certificate of Compliance

**Certificate:** 1684744

**Master Contract:** 230765

**Project:** 80111508

**Date Issued:** December 21, 2021

**Issued to:** Telemecanique/Schneider Electric  
Industries SAS  
BP 660  
Zone Industrielle No. 3  
L'Isle d'Espagnac, 16340  
FRANCE

*The products listed below are eligible to bear the CSA Mark shown*



**Issued by:** *Faith A. Caprio*  
Faith A. Caprio

## PRODUCTS

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

- Protection module, series RUW240BD, RUW241P7, RUW242B7, RUW242P7, RXM021BN, RXM021FP, RXM021RB, RXM041BN7, RXM041FU7, RXM040W, rated 240V ac max, 250V dc max, 1 phase, 60 hz.
- Relay sockets, open type, Cat Nos RPZF2, RPZF3, rated at 300V 16A per pole; at 600V Limited rating 5A per pole, 10A multipole.
- Relay sockets, open type, Cat Nos RPZF4, RUZC2M, RUZC3M, RXZE2M114, RXZE2M114M, RXZE2S111M, and RXZE2S114M rated at 300V Limited rating 10A per pole, 20A multi-pole.
- Relay sockets, open type, Cat No. RUZSC2M, RUZSC3M, and RXZE2S108M rated at 300V ac 12A per pole
- Relay socket, open type, Cat No. RUZSF3M rated at 300V ac 25A per pole.

■ [REDACTED]

■ [REDACTED]

■ [REDACTED]



**Certificate:** 1684744  
**Project:** 80111508

**Master Contract:** 230765  
**Date Issued:** December 21, 2021

[REDACTED]

Notes:

1. Open type devices are certified as components for use only in other certified equipment where the suitability of the combination is to be determined by CSA International.
2. The wiring terminals are not suitable for field wiring. The wiring terminals are to be factory wired only and the suitability of the connection shall be determined.

- Relay sockets, open type:

Type RPZF1 rated 300V ac, 20A.

Notes:

1. Open type devices are Certified as components for use only in other Certified equipment where the suitability for the combination is determined by the CSA International.
2. Suffix letters and numbers denote contact form, contact rating, type of case and coil voltage.

- Solid state relays, open type, Cat. Nos. SSRPP8S90A3 and SSRPP8S125A3, rated input voltage 90-280 Vac; output voltage 48-660 Vac; output current 125A max.
- Solid state relays, open type, Cat. Nos. SSRPCDS90A3 and SSRPCDS125A3, rated input voltage 3-32 Vdc; output voltage 48-660 Vac; output current 125A max.

Note:

Open type devices are Certified as components for use only in other Certified equipment where the suitability of the combination is to be determined by the CSA International.

- Solid state relays, open type, fully encapsulated, Cat. Nos. SSRPCDS50A1 rated input voltage 3-32 Vdc; output voltage 240 Vac; output current 90A max.

Notes:

1. Certified only as a component of other certified equipment, where the suitability of the combination is to be determined by CSA International.
2. Sold only to manufactures for factory assembly of certified electrical equipment.
3. Rating for the above relays is based on the use of the external aluminium heatsink specified by the submitter's published literature.

- Solid state relays, open type, Cat. Nos. SSRDCDS45A1, rated input voltage 3-32 Vdc or 4-32 Vdc; output voltage 24-280 Vac or 48-660 Vac; output current 65A.
- Solid state relays, open type, Cat. Nos. SSRDF8S45A1, rated input voltage 90-140 Vac; output voltage 24-280 Vac or 48-660 Vac; output current 65A.



**Certificate:** 1684744  
**Project:** 80111508

**Master Contract:** 230765  
**Date Issued:** December 21, 2021

**Note:**

Open type devices are Certified as components for use only in other Certified equipment where the suitability of the combination is to be determined by the CSA International.

- Solid state relays, SSRPCDS75A2, rated input voltage 4-32 Vdc, output voltage 600 Vac, output current 90A max.

**Notes:**

1. Certified only as a component of other Certified equipment, where the suitability of the combination is to be determined by CSA International.
2. Sold only to manufacturers for factory assembly of Certified electrical equipment.
3. Rating for the above relays is based on the use of the external aluminum heatsink specified by the submitter's published literature.

**Note:**

Open type devices are Certified as components for use only in other Certified equipment where the suitability of the combination is to be determined by the CSA International.

- Solid state relays, open type, with integral heatsink, Cat. Nos. SSRDP8S10A1, SSRDP8S20A1, SSRDP8S30A1, rated input voltage 90-280 Vac; output voltage 480 Vac max, 30A max.
- Solid state relays, open type, with integral heatsink, Cat. Nos. SSRDCDS10A1, SSRDCDS20A1, SSRDCDS30A1, rated input voltage 4.5-32V dc; output voltage 480 Vac max, 30A max.

**Note:**

Open type devices are Certified, as components, for use only in other Certified equipment where the suitability of the combination is determined by CSA International.

- Solid state relays, open type, Cat. Nos. SSRPP8S10A1, SSRPP8S25A1, SSRPP8S50A1, SSRPP8S75A2, rated input voltage 90-280 Vac; output voltage 280 Vac max; output current 75A max.
- Solid state relays, open type, Cat. Nos. SSRPCDS10A1, SSRPCDS25A1, rated input voltage 3-32 Vdc, output voltage 280 Vac max; output current 50A max.
- Solid State DC Relays, open type, Series 1-DC, Models SSRPCDM12D5, SSRPCDM25D5 and SSRPCDM40D5, rated output 0-100 V dc, 40 A max, control voltage 3.5-32 V dc.

**Notes:**

1. Certified only as a component of other Certified equipment, where the suitability of the combination is to be determined by CSA International.
2. Sold only to manufacturers for factory assembly of Certified electrical equipment.
3. Rating for the above relays is based on the use of the external aluminum heatsink specified by the submitter's published literature.

**APPLICABLE REQUIREMENTS**

- CSA - C22.2 No. 14-18 - Industrial Control Equipment.
- UL Std. No. 508, 17<sup>th</sup> Edition - Industrial Control Equipment



**Certificate:** 1684744  
**Project:** 80111508

**Master Contract:** 230765  
**Date Issued:** December 21, 2021

---

### **MARKINGS**

- Products shall be marked with the markings specified by the particular product standard.
- Products certified for Canada shall have all Caution and Warning markings in both English and French.

Additional bilingual markings not covered by the product standard(s) may be required by the Authorities Having Jurisdiction. It is the responsibility of the manufacturer to provide and apply these additional markings, where applicable, in accordance with the requirements of those authorities.

The products listed are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US (indicating that products have been manufactured to the requirements of both Canadian and U.S. Standards) or with adjacent indicator 'US' for US only or without either indicator for Canada only.

Listee's name and/or CSA file number 230765, model designation, complete electrical rating in volts, hertz, hp, amps, serial number or date coding, and the CSA Mark appear in a permanent manner on each unit.



## Supplement to Certificate of Compliance

**Certificate:** 1684744

**Master Contract:** 230765

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### Product Certification History

Project	Date	Description
80111508	December 21, 2021	Update Multiple Listing to Delete below Models. Model comparison with Delisted Report 168986 - 80001663. Classes: 3211 07, 3211 87. <div style="display: flex; justify-content: space-between;"> <div style="width: 45%;"> <p><u>Submitter Models:</u>            I.O.-IAC-RO-280            I.O.-IAC+RO-280            I.O.-IDC-RO-028            I.O.-IDC+RO-028            I.O.-OAC-RO-280            I.O.-OAC-RA-280            I.O.-ODC-RO-060            I.O.-ODC-RL-060</p> </div> <div style="width: 45%;"> <p><u>Listee Models:</u>            SSLM1ND101M7            SSLM1D101M7            SSLM1ND101BD            SSLM1D101BD            SSLM1A13BD            SSLM1A13M7            SSLM1D23BD            SSLM1LD23BD</p> </div> </div>
80033254	February 7, 2020	<div style="display: flex; justify-content: space-between;"> <div style="width: 45%;"> <p><u>Submitter Models:</u>            I.O.-IAC-RO-280            I.O.-IAC+RO-280            I.O.-IDC-RO-028            I.O.-IDC+RO-028            I.O.-OAC-RO-280            I.O.-OAC-RA-280            I.O.-ODC-RO-060            I.O.-ODC-RL-060</p> </div> <div style="width: 45%;"> <p><u>Listee Models:</u>            SSLM1ND101M7            SSLM1D101M7            SSLM1ND101BD            SSLM1D101BD            SSLM1A13BD            SSLM1A13M7            SSLM1D23BD            SSLM1LD23BD</p> </div> </div>
2274033	February 12, 2010	Transfer of Multiple Listing 230765- 1684744 due to the transfer of products between Telemecanique/Schneider Electric Industries SAS, L'Isle d'Espagnac (4756362) to Telemecanique/Schneider Electric Industries SAS, L'Isle d'Espagnac (4703490). Only change of listee ID number.
2225676	October 1, 2009	<div style="display: flex; justify-content: space-between;"> <div style="width: 45%;"> <p><u>Submitter Models:</u>            6210AXXSZS-AC90            6225AXXSZS-AC90            6250AXXSZS-AC90            6475AXXSZS-AC90            6690AXXSZS-AC90            66125AXXSZS-AC90            6210AXXSZS-DC3            6225AXXSZS-DC3            6250AXXSZS-DC3            6475AXXSZS-DC3            6690AXXSZS-DC3            66125AXXSZS-DC3            SSR210DIN-AC22            SSR220DIN-AC22            SSR230DIN-AC22            SSR210DIN-DC22</p> </div> <div style="width: 45%;"> <p><u>Listee Models:</u>            SSRPP8S10A1            SSRPP8S25A1            SSRPP8S50A1            SSRPP8S75A2            SSRPP8S90A3            SSRPP8S125A3            SSRPCDS10A1            SSRPCDS25A1            SSRPCDS50A1            SSRPCDS75A2            SSRPCDS90A3            SSRPCDS125A3            SSRDP8S10A1            SSRDP8S20A1            SSRDP8S30A1            SSRDCDS10A1</p> </div> </div>



**Certificate:** 1684744  
**Project:** 80033254

**Master Contract:** 230765  
**Date Issued:** 2020-02-07

SSR220DIN-DC22  
SSR230DIN-DC22  
SSR245DIN-AC45  
SSR245DIN-DC45  
D1D12  
D1D40  
D1D40

SSRDCDS20A1  
SSRDCDS30A1  
SSRDF8S45A1  
SSRDCDS45A1  
SSRPCDM12D5  
SSRPCDM25D5  
SSRPCDM40D5

2035741      May 7, 2008      Transfer of Multiple Listing due to the transfer of products between Telemecanique Nanterre and Telemecanique L'Isle d'Espagnac. Only change of listee ID number.

1803929      June 16, 2006

Submitter Models:

████████████████████  
████████████████████  
████████████████████  
████████████████████

RPZF1  
70-782-D8-1  
70-782D-1  
70-782D  
70-783D11-1  
70-783D-1  
70-784D14-1  
70-784D-1  
70-750E8-1  
70-750E11-1  
70-750EL8-1  
70-750EL11-1  
70-788EL11-1  
70-782D14-1  
70-782E14-1  
70-782EL8-1  
70-782EL11-1  
70-782EL14-1

Listee Models:

████████████████████  
████████████████████  
████████████████████  
████████████████████

RPZF1  
RPZF2  
  
RPZF3  
  
RPZF4  
  
RUZC2M  
RUZC3M  
RUZSC2M  
RUZSC3M  
RUZSF3M  
RXZE2M114  
RXZE2M114M  
RXZE2S108M  
RXZE2S111M  
RXZE2S114M

1684744      July 20, 2005

Submitter Models:

70-ASMD-250  
70-ASMR-240  
70-ASMM-24  
70-ASMM-240  
70-BSMM-24V  
70-BSMM-120V  
70-BSMM-240V  
70-BSMR-60  
70-BSMR-240  
70-BSMD-250D

Listee Models:

RUW240BD  
RUW241P7  
RUW242B7  
RUW242P7  
RXM021BN  
RXM021FP  
RXM021RB  
RXM041BN7  
RXM041FU7  
RXM040W