

Certificate of Compliance

Certificate: 1596812 (LR 88980)

Project: 1596812

Issued to: Merlin Gerin, (d/b/a)

Schneider Electric Industries S A S DMAT/ABT S2A ave des Jeux Olympiques Grenoble Cedex 9, 38050 France Attention: Mr. Antoine Pantalone Master Contract: 177007

Date Issued:

September 24, 2004

The products listed below are eligible to bear the CSA Mark shown



Issued by: R. Tateishi, P. Eng.

Authorized Nick Alfano, Operations Manager by:



PRODUCTS

Moulded case switches, Powerpact P, Cat. No. Prefixes PG, PJ, PK and PL, 2-, 3- and 4-pole, 600, 800, and 1200A, 600V ac max.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures