

Certificate of Compliance

Certificate Number E181374-20050816
Report Reference E181374, August 16, 2005
Issue Date 2005 August 29

Page 1 of 1



Issued to: **Square D Co.**
3700 6th Street S.W.
Cedar Rapids, IA. 52404

This is to certify that representative samples of

Circuit Breaker Equipment with Ground Fault Protection
Catalog Number Prefix ED, EG & EJ Series 1.

Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety:


UL 1053 Ground-Fault Sensing and Relaying Equipment
UL 489 Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures

Additional Information:

Ratings: 277 v, 15-50A, 28-32mA trip level for ground fault sensing and relay module.

| Interrupting Ratings: | Frame | Current Interrupting Rating |
|-----------------------|-------|-----------------------------|
| | ED | 18,000 |
| | EG | 35,000 |
| | EJ | 65,000 |

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: *Benny Jackson*
Benny Jackson, Assoc. Project Engineer
Underwriters Laboratories Inc.

Reviewed by: *Antonio Romanacce*
Antonio Romanacce, Manager
Underwriters Laboratories Inc.