

**IEC****IECEE**

®

™

Ref. Certif. No.

CN70520

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

AC contactor

Name and address of the applicant

Schneider Shanghai Industrial Control Co., Ltd.  
No.629 Suide Road, Putuo District, Shanghai, P.R.China

Name and address of the manufacturer

Schneider Electric Industries SAS  
35 Rue Joseph Monier 92500 Rueil-Malmaison, France

Name and address of the factory

Schneider Shanghai Industrial Control Co., Ltd.  
No.629 Suide Road, Putuo District, Shanghai, P.R.China*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

See the Appendix

Trademark (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

LC1D40A, LC1D50A, LC1D65A;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-1:2020;IEC 60947-4-1:2023

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2024CQC-117077

**CHINA QUALITY CERTIFICATION CENTRE CO., LTD.**

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Jan.10,2025

Signature:

谢肇煦

Xie ZhaoXu



LC1D40A, LC1D50A, LC1D65A

Ui: 690V;

Uimp: 6kV;

LC1D40A:

Ith: 60A;

AC-1: Ue/Ie: 230V/60A, 400V/60A, 440V/60A, 500V/60A, 690V/60A;

AC-3: Ue/Ie: 230V/38A, 400V/35A, 440V/40A, 500V/33A, 690V/32A;

AC-3e: Ue/Ie: 230V/38A, 400V/35A, 440V/40A, 500V/33A, 690V/32A;

AC-4: Ue/Ie: 230V/38A, 400V/35A, 440V/40A, 500V/33A, 690V/21A;

LC1D50A:

Ith: 80A;

AC-1: Ue/Ie: 230V/80A, 400V/80A, 440V/80A, 500V/80A, 690V/80A;

AC-3: Ue/Ie: 230V/51A, 400V/41A, 440V/50A, 500V/44A, 690V/35A;

AC-3e: Ue/Ie: 230V/51A, 400V/41A, 440V/50A, 500V/44A, 690V/35A;

AC-4: Ue/Ie: 230V/51A, 400V/41A, 440V/50A, 500V/33A, 690V/21A;

LC1D65A:

Ith: 80A;

AC-1: Ue/Ie: 230V/80A, 400V/80A, 440V/80A, 500V/80A, 690V/80A;

AC-3: Ue/Ie: 230V/61A, 400V/55A, 440V/65A, 500V/53A, 690V/39A;

AC-3e: Ue/Ie: 230V/61A, 400V/55A, 440V/65A, 500V/53A, 690V/39A;

AC-4: Ue/Ie: 230V/61A, 400V/55A, 440V/50A, 500V/33A, 690V/21A;

Us:

50Hz: AC12V;

60Hz: AC24V, 120V, 208V, 277V, 480V;

50/60Hz: AC24V, 32V, 42V, 48V, 100V, 110V, 115V, 127V, 200V,

220V, 230V, 240V, 380V, 400V, 415V, 440V, 500V, 575V, 600V, 660V, 690V;

DC: 12V, 24V, 36V, 48V, 60V, 72V, 110V, 125V, 220V;

Electronic coils:

DC: 24V;

50/60Hz/DC: 24-60V, 48-130V, 100-250V;

Page 1 of 2

Additional information (if necessary)

Date:

Jan.10,2025

Signature:

谢肇煦

Xie ZhaoXu

IEC

TECEE

®

™

Ref. Certif. No.

CN70520

Pole: 3P;

Frequency: 50/60Hz;

IP20(from front face only)

Auxiliary contacts: (body)

Ith:10A;

AC-15: Ue/Ie: 120V/6A, 690V/1.04A;

DC-13: Ue/Ie: 125V/1.1A, 600V/0.2A;

1NO+1NC

Page 2 of 2

Additional information (if necessary)

Date:

Jan.10,2025

Signature:

谢肇煦

Xie ZhaoXu