



Certificate of Compliance

Certificate: 1413940 (LR 92886-35)

Master Contract: 153555

Project: 2577321

Date Issued: November 13, 2012

Issued to: Schneider Electric USA, Inc.

Square D
3700 6th St SW
Cedar Rapids, IA 52404
USA
Attention: Jan Harper

The products listed below are eligible to bear the CSA Mark shown



R. Tateishi

Issued by: R. Tateishi, P. Eng.

PRODUCTS

CLASS 1432 01 - CIRCUIT BREAKERS - Moulded Case Type

Circuit breakers, Type QOA and QOB, common trip, thermal magnetic trip uncompensated, two-pole, 40-100A, 240V ac max.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures