



CERTIFICATE OF COMPLIANCE

CERTIFICATE NUMBER: 140601-E84967A

ISSUE DATE: June 14, 2001

Page 1 of 1

Issued to: Square D Company
3700 6th Street S.W.
Cedar Rapids, IA. 52404 USA

Report Reference: E84967, March 19, 1992

This is to Certify that
representative samples of: Molded-Case Circuit Breakers, Type QO and QOB with Catalog Number
Prefix QO or QOB


Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s)
indicated on this Certificate.

Standard(s) for Safety: UL 489, Molded-Case Circuit Breakers and Circuit Breaker Enclosures

Additional Information: These are three pole circuit breakers with the following ratings:

Three pole rated 70 thru 100A maximum, three phase, 240 V ac maximum,
60 Hz, Current Interrupting Rating is 10,000 A.

Only those products bearing the UL Listing Mark should be considered as being covered by
UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control
number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate
UL Directory.

LOOK FOR THE UL LISTING MARK ON THE PRODUCT

Engineer: *Lawrence R. Smith*
Lawrence R. Smith, Staff Eng. Assoc.
Underwriters Laboratories Inc.

Review Engineer: *Michael S. Mayes*
Michael S. Mayes, Staff Eng. Assoc.
Underwriters Laboratories Inc.