Ref. Certif. No.

DK-125508-UL

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	ZBRN: Configurable Harmony Hub. Gateway for wireless transmitters; ZBRR: Programmable or configurable receivers; ZBRA1: Relay Antenna, AC/DC.
Name and address of the applicant	Schneider Electric / DBA Telemecanique Zone Industrielle BP660 L'Isle D'Espagnac 16340 France
Name and address of the manufacturer	Schneider Electric / DBA Telemecanique Zone Industrielle BP660 L'Isle D'Espagnac 16340 France
Name and address of the factory Note: *When more than one factory, please report on page 2*	PT. SCHNEIDER ELECTRIC MANUFACTURING BATAM Batamindo Industrial Park JL Beringin Lot 1, 4 & 208 Muka Kuning Batam 29433 Indonesia ☐ Additional Information on page 2
Ratings and principal characteristics	ZBRN1 : 24-240 Vac, 180-48mA, 50/60Hz 24-240Vdc, 117-12mA ☒ Additional Information on page 2
Trademark (if any)	Schneider Electric
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	ZBRN1, ZBRN2, ZBRRA, ZBRRC, ZBRRD, ZBRRH, ZBRA1 ☐ Additional Information on page 2
Additional information (if necessary may also be reported on page 2)	**Additionally evaluated to:** EN 61010-1:2010, EN 61010-1:2010/A1:2019, EN IEC 61010-2-201:2018 National Differences specified in the CB Test Report ☐ Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 61010-1:2010, IEC 61010-1:2010/AMD1:2016, IEC 61010-2-201:2017
As shown in the Test Report Ref. No. which forms part of this Certificate	E520857-D1000-1/A0/C0-CB issued on 2022-03-16

This CB Test Certificate is issued by the National Certification Body

☐ UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
☒ UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
☐ UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
☐ UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2022-03-25

Signature: Jan-Erik Storgaard

Additional Ratings:

ZBRN2 :
24-240 Vac, 155-50mA, 50/60Hz
24-240 Vdc, 90-11mA

ZBRRA, ZBRRD: 24-240 Vac/dc, 3W, 50-60Hz;
ZBRRC, ZBRRH: 24 Vdc, 0.8W;
ZBRA1: 24-240 Vac/dc, 3W, 50-60Hz.

Additional information (if necessary)

☐ UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
☒ UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
☐ UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
☐ UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2022-03-25

Signature:
Jan-Erik Storgaard