



Certificate of Compliance

Certificate: 1534832 (LR 40970)

Master Contract: 153555

Project: 70036964

Date Issued: July 23, 2015

Issued to: Schneider Electric USA, Inc.

Square D
3700 6th St SW
Cedar Rapids, IA 52404
USA
Attention: Jerry Beasler

The products listed below are eligible to bear the CSA Mark shown



R. Tateishi

Issued by: R. Tateishi, P. Eng.

PRODUCTS

CLASS 1432 01 - CIRCUIT BREAKERS - Moulded Case Type

Molded case circuit breakers, Powerpact HD, HG, HJ, HL and HR, 2- and 3-pole, 150A max, 600V ac max, 250V dc max.

Molded case circuit breakers, Powerpact HG and HL, 3-pole, 70A max, 500V dc nominal, 600V dc max, intended for use on UPS ungrounded systems only, all 3 poles wired in series.

Molded case circuit breakers, Powerpact JD, JJ, JL and JR, 2- and 3-pole, 250A max, 600V ac max, 250V dc max.

Molded case circuit breakers, Powerpact JG, 2- and 3-pole, 250A max, 600V ac max, 500V dc max.

Molded case circuit breakers, Powerpact JG and JL, 3-pole, 250A max, 500V dc nominal, 600V dc max, intended for use on UPS ungrounded systems only, all 3 poles wired in series.

Molded case circuit breakers, Powerpact JD-W, JG-W, JJ-W, and JL-W, 3 pole, electronic trip, 250A max, 480Y/277V ac.

CLASS 1437 01 - CIRCUIT BREAKERS - Accessories



Certificate: 1534832 (LR 40970)

Master Contract: 153555

Project: 70036964

Date Issued: July 23, 2015

External neutral current transformers, Cat. Nos. LV429521, LV430563, LV432575, S429521, S430562, S430563, and S432575 for use with the submittor's Certified moulded case circuit breakers, Cat. No. Prefixes H, J, L and NSX.

Notes:

These circuit breakers may also be brand labelled for Merlin Gerin and Federal Pacific and bear the Cat No Prefixes NHD, NHG, NHJ, NHL, NHR, NJD, NJG, NJJ, NJL and NJR; PHD, PHG, PHJ, PHL, PHR, PJD, PJG, PJJ, PJJ and PJR and respectively.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures