

CERTIFICATE OF COMPLIANCE

Certificate Number 20130102 – E84967
Report Reference E84967 - 19920324
Issue Date 2013-January-02

Issued to: SCHNEIDER ELECTRIC USA INC / SQUARE D CO
1010 AIRPARK CENTER DR
NASHVILLE, TN 37217 USA

**This is to certify that
representative samples of**

Circuit Breakers, Molded Case and Circuit-breaker Enclosures
Molded case circuit breakers used as main breakers. Type
QOM1 and QOM1A. Covered in this section of the Procedure
are uncompensated thermal circuit breakers rated 50 to 60 A and
70 to 125 A. All breakers have a temperature rating of 40°C.

(See following page for additional model information.)

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety:

ANSI/UL 489, "Molded-Case Circuit Breakers, Molded-Case
Switches and Circuit-Breaker Enclosures" and CAN/CSA-C22.2
No. 5 (2002), "Molded-Case Circuit Breakers, Molded-Case
Switches and Circuit Breaker Enclosures."

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20130102 – E84967
Report Reference E84967 - 19920324
Issue Date 2013-January-02

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Additional Model Information:

Electrical Ratings:

Type QOM1 circuit breakers are two pole common trip devices, rated 120/240 V ac; 50, 60, 70, 80, 90 and 100 A. Type QOM1A 120/240 V ac, 110 and 125 A.

<u>Breaker Type</u>	<u>Rating, A</u>	<u>Rating</u>	<u>Interrupting Cat. No.</u>
QOM1	50-100	22,000	QOM***VH
QOM1A	110, 125	22,000	QOM***VH
QOM1	50-100	10,000	QOM***
QOM1A	110-125	10,000	QOM***



William R. Carney, Director, North American Certification Programs
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

