



Certificate of Compliance

Certificate: 1509070 (LR 29971-28)

Master Contract: 153555

Project: 2279539

Date Issued: 2010/03/02

Issued to: Schneider Electric USA, Inc.

Square D
3700 6th St SW
Cedar Rapids, IA 52404
USA
Attention: Jan Harper

The products listed below are eligible to bear the CSA Mark shown



R. Tateishi, P. Eng.

Issued by: R. Tateishi, P. Eng.

PRODUCTS

CLASS 1451 01 - GROUND FAULT DEVICES - Circuit Interrupters

Combined circuit breaker and ground fault interrupter, 30mA sensitivity, Type QO-EPD and QOB-EPD, Series 2, 1-pole, 15-30A, 120V ac and 2-pole, 15-60A, 120/240V ac.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures

CAN/CSA-C22.2 No. 144 - Ground Fault Circuit Interrupters