CN49825-M2

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

AC contactor

Name and address of the applicant

Schneider Shanghai Industrial Control Co., Ltd. No.629 Suide Road, Putuo District, Shanghai, P.R.China

Name and address of the manufacturer

Schneider Electric Industries SAS

35 Rue Joseph Monier, 92500 Rueil-Malmaison France

Name and address of the factory

Schneider Electric a. s.

Note: When more than one factory, please report on page 2

Cizovska 447 - 39701 Pisek - Czech Republic

Ratings and principal characteristics

See the Appendix

Trademark (if any)

Schneider Electric

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

LC1F630, LC1F780, LC1F6304, LC1F7804;

Additional information (if necessary may also be reported on page 2)

The latest CB certificate No. is CN49825-M1, dated 2021-08-09. The issuance of the M2 certificate is to change parameters.

A sample of the product was tested and found to be in conformity with

IEC 60947-4-1:2018;IEC 60947-1:2007;IEC

As shown in the Test Report Ref. No. which

60947-1:2007/AMD1:2010;IEC 60947-1:2007/AMD2:2014

forms part of this Certificate

00901-CB2019CQC-090420-M2

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China Tel: +86-10-83886666 Fax: +86-10-83886282

website: http://www.cqc.com.cn

Date: Apr.18,2024







CN49825-M2

LC1F630, LC1F780, LC1F6304, LC1F7804

Uimp: 8kV;

Ui: 1000V;

LC1F630:

Ith:1000A;

AC-3: Ue/le: AC230V/608.7A, 400V/575A, 415V/622.2A, 440V/630A, 500V/552A,

690V/446.7A,1000V/308.2A;

AC-1: Ue/le: AC230V/400V/415V/440V/500V/690V/1000V/1000A;

3P;

LC1F780:

Ith: 1600A;

AC-3: Ue/Ie: AC230V/664.9A, 400V/690A, 415V/704A, 440V/780A, 500V/616.5A,

690V/469.8A, 1000V/308.2A;

AC-1: Ue/le: AC230V/400V/415V/440V/500V/690V/1000V/1600A;

3P;

LC1F6304:

Ith: 1000A;

AC-1: Ue/le: AC230V/400V/415V/440V/500V/690V/1000V/1000A;

4P;

LC1F7804:

Ith: 1600A;

Page 1 of 2

Additional information (if necessary)

Apr.18,2024

Date:

Signature:



Tel: +86-10-83886666 Fax: +86-10-83886282

website http://www.cqc.com.cn



CN49825-M2

AC-1: Ue/le: 230V/400V/415V/440V/500V/690V/1000V/1600A;

4P;

Us:AC48V, 110V, 115V, 200-208V, 220V, 230V, 240V, 380V, 400V, 415V,

440V(AC40...400Hz);

DC48V, 110V, 125V, 220V, 250V, 440V;

AC100-250V 50-60Hz /DC100-380V(only available for LC1F630, LC1F6304);

Frequency: 50/60Hz

Page 2 of 2

Additional information (if necessary)

Date:

Apr.18,2024

新肇煦 Xie ZhaoXu

Tel: +86-10-83886666

Fax: +86-10-83886282