

Certificate of Compliance

Certificate Number **20091130 – E48340**
Report Reference **E48340, 2009 November 12**
Issue Date **2009 November 14**

Page 1 of 1



Issued to: **SQUARE D CO**
3700 6TH ST SW
CEDAR RAPIDS, IA 52404 USA

This is to certify that representative samples of

Circuit Breaker and Ground-fault Circuit Interrupters

Model Descriptions: Circuit breaker and ground fault circuit interrupter, Types QO and QOB, series 1.


Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: **The basic standards used to investigate products in this category are ANSI/UL 489, "Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures," and ANSI/UL 943, "Ground-Fault Circuit-Interrupters."**

Additional Information: **This product is a three pole Class "A" ground fault interrupter rated 208Y/120 VAC, 15A, 20A, 30A, 40A & 50A.**

These circuit breakers maybe accessorized with an Auxilary Switch, contact type A or B or an Alarm Switch.

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

William Carney
Director, North American Certification Programs