



Certificate of Compliance

Certificate: 2279428 (LR 29971)

Master Contract: 153555

Project: 2460936

Date Issued: October 4, 2011

Issued to: Schneider Electric USA, Inc.

Square D
3700 6th St SW
Cedar Rapids, IA 52404
USA
Attention: Jan Harper

The products listed below are eligible to bear the CSA Mark shown



R. Tateishi

Issued by: R. Tateishi, P. Eng.

PRODUCTS

CLASS 1451 01 - GROUND FAULT DEVICES - Circuit Interrupters

Combined circuit breaker with equipment ground fault protection, 30mA sensitivity, Types HOM and CHOM, Series 1, 1-pole, 15 and 20A, 120V ac.

Notes:

1. These devices are Certified for use only in enclosures where the suitability has been determined by CSA International.
2. These devices are not for electrical shock hazard protection and are not suitable for use where the Canadian Electrical Code, Part I requires that a "Class A" interrupter be used.
3. These devices may bear a high interrupting rating of 10kA rms symmetrical amperes, 120V ac.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures

CAN/CSA-C22.2 No. 144 - Ground Fault Circuit Interrupters